



Managed by Fermi Research Alliance, LLC for the U.S. Department of Energy Office of Science

MARS analysis, Radiation maps

Vitaly Pronskikh

Remote Handling Review Dry Run



16 February 2015

Residual dose from the target (Au-198, 25 kW)

Contact dose 1yr/7d

Size scaling factor

Distance scaling factor





$$D(x, y, z) = k_d \Phi(x, y, z)$$

$$= k_d \int dS \frac{A_s}{2\pi\rho^2}$$

$$f(r - R) \equiv \frac{D(r)}{D_0}$$

$$f(100) = 0.0023$$

Figure 5: The calculated dose scaling factors, R_g , for solid cylinders of various materials vs. the normalized diameter. The lines are drawn to guide the eye.



The finite length correction factors


$$ffs = \frac{\Phi^{short}}{\Phi^{long} * k_{vol}}$$

$$ffs(100) = 0.0611.$$


$$D(100 \text{ cm}) = 1.15 \text{ Sv/hr}$$

Residual dose from the target (W-184) and cask thickness


Residual dose on contact (365d/7d), mSv/hr



W target at 6×10^{12} p/s, irradiation time 365 d




W target at 6×10^{12} p/s, irradiation time 365 days



~1350 nuclides, $1.7 \text{ E}13 \text{ Bq}$ (365/7), 1 MeV

Photon prompt dose equivalent, mSv/hr



Cooling time	Lt, steel, in	Ll, steel, in
0 d	10.6	11.8
1 d	10.0	11.3
7 d	10.0	11.0
30 d	9.6	11.0

Steel (in)	DoseRate (mrem/hr)
1	1.06E+06
2	4.61E+05
4	7.00E+04
6	9.09E+03
8	1078
10	120
12	13
14	1.3
16	0.1



To reduce the dose to 1 mSv/hr

Kamran Vaziri




Space frame residual activation



Stainless steel (tubes and ring), W (rods), W(target)





Contact dose, mSv/hr





Contact dose on HRS and AI magnet stabilizer



Contact dose on HRS and AI magnet stabilizer



Residual doses in the extinction rooms



For 1 yr/ 4 hr the dose is 17 mrem/hr and 0.14 mrem/hr.
The doses are given at the centers of the rooms.


Residual doses in the RHR (1yr/7d), mrem/hr

Surface	Max	Min
Ceiling	1.9	0.08
Floor	1.6	0.1
West	0.3	0.1
East	0.2	0.09
North	0.04	0.03
South	1.3	0.1

The data bins are ~1x1 m sized

Residual dose due to the beam absorber

cm
Residual dose at shower max at 3.3E12 p/s, mSv/hr, w/yoke NEW (30d/1d)



- irr\cool,d

	1	2	7	30	183
30	1.00E+00	4.10E-01	9.25E-02	4.69E-02	9.23E-03
365	1.16E+00	5.68E-01	2.47E-01	8.54E-02	6.48E-02

