

# LHC Cryogenics Availability & Helium Management from Run 1 to Run 2

7<sup>th</sup> International Workshop on Cryogenics Operation

25 – 27 October 2016

Fermi National Accelerator Laboratory

Laurent Delprat

On behalf of the cryogenic operation team

*With contribution from K. Brodzinski and G. Ferlin*



[Laurent.Delprat@cern.ch](mailto:Laurent.Delprat@cern.ch)

Cryo-Ops 2016




# CONTENTS

## Introduction – LHC Cryogenic System Architecture

- ➔ Cryoplants reliability
- ➔ Cryogenic system availability
- ➔ Helium inventory management


## Conclusion – Perspectives

# LHC Cryogenic System Architecture



**Total for 8 sectors:**

- Compressors: 64
- Turbines: 74
- Cold Comp.: 28
- Leads: 1'200
- I/O signals: 60'000
- PID loops: 4'000



# LHC CRYOPLANTS RELIABILITY

# Run 2 main failures impacting availability

2015

3 turbines failures on 4.5 K refrigerators

1 warm compressor failure on 4.5 K refrigerator

16 RFL valves failures

4 PLCs failures

1 major internal helium leak towards vacuum chamber on 4.5 K refrigerator

2016

1 motor degradation on 4.5 K refrigerator


1 warm compressor degradation on 4.5 K refrigerator

1 PLC failure


*Additional problem encountered in 2016:*

1 smooth clogging of inlet filter on the VLP line of a 1.8 K unit (yet no induced downtime)

Pressure drop over inlet filter on VLP line of 1.8 K unit, B type, LHC point 4




# LHC Cryoplants Stops by category, from RUN1 to RUN2



Preliminary




# 2015 LHC Cryoplants Stops by category







# 2016 LHC Cryoplants Stops by category



# LHC 4.5 K Cryopants Reliability



# LHC 1.8 K Units Reliability



■ Number of 1.8 K units failures    
 ■ Number of 1.8 K units in operation    
 —■ Total associated downtime

2

1.5

1.85

1.6


0.5

Failure rate




# LHC CRYOGENIC SYSTEM AVAILABILITY

# Cryogenic conditions definition



*Interface with the client*



### 3 ways to lose availability:


- Act directly on level or temperature **Quench**
- Act on one of the 4 root causes **Technical Services or Cryo Equipment**
- The context **Ask for delayed injection**



# Availability losses categorization

AFT category	AFT sub-category	Sub systems used for statistics	Comments
CRYOGENICS	EQUIPMENT	CRYO-PROD-4.5K	Compressors, ORS, dryers, turbines, ADS - any mechanical failure
		CRYO-PROD-1.8K	Compressors, ORS, turbines, ADS - any mechanical failure
		CRYO-PROD-QUI	Any failure related to QUI
		CRYO-PROD-VAC	Insulation vacuum of cold boxes and QUI
		CRYO-PROD-INSTRUM	Valves, electrical heaters, sensors
		CRYO-PROD-CONTROL	Software
		CRYO-PROD-PLC	Surface installations PLCs
		CRYO-PROD-SEU	Single event upsets in electronics due to radiation in operation environment
		CRYO-PROD-OTHER	Other cryo production related issue
		CRYO-TUNNEL-INSTRUM	Sensors, electrical heaters (except for EH893, under TE-MPE responsibility), valves
		CRYO-TUNNEL-CONTROL	Software
		CRYO-TUNNEL-PLC	Tunnel installations PLCs
		CRYO-TUNNEL-SEU	Single event upsets in electronics due to radiation in operation environment
		CRYO-TUNNEL-OTHER	Other cryo tunnel related issue
		CRYO-OP-PNO-DFB	LHe level oscillation in a distribution feed box
		CRYO-OP-PNO-SAM	LHe level oscillation in a standalone magnet
		CRYO-OP-PNO-REF	Refrigerator tuning not optimized
		CRYO-OP-PNO-BSCR	Beam screen regulation related issue
	CRYO-OP-PNO-HF	Human factor in cryogenics operation, causing downtime (human or procedure)	
	CRYO-OP-PNO-OTHER	Other non-optimization leading to downtime	
	USERS	USERS-QUENCH	Quench
		USERS-QPS	Quench protection system related issue
		USERS-ELQA	ELQA
		USERS-OTHER	Other users related issue
	TECHNICAL SERVICES	TECHNICAL SERVICES-CV	Cooling and ventilation
		TECHNICAL SERVICES-EL	Electricity
		TECHNICAL SERVICES-CAIR	Compressed air
		TECHNICAL SERVICES-SECTORS VAC	Insulation vacuum in sectors
		TECHNICAL SERVICES-NET	Controls / Network
TECHNICAL SERVICES-EH893 DFB		Top flange heaters of distribution feed boxes (under TE-MPE responsibility)	
TECHNICAL SERVICES-OTHER		Other technical services related issue	

# LHC RUN 2 Overall availability (Cryo Maintain)




Preliminary





# Typical follow-up



# 2015 to 2016 Overall availability (Cryo Maintain)



CRYO LOSSES		USERS LOSSES		SUPPLY LOSSES		TOTAL LOSSES	
Number	Time	Number	Time	Number	Time	Number	Time
164	273:29:00	32	122:19:00	7	61:43:00	203	457:31:00

2015




2016

CRYO LOSSES		USERS LOSSES		SUPPLY LOSSES		TOTAL LOSSES	
Number	Time	Number	Time	Number	Time	Number	Time
16	73:21:00	22	55:26:00	7	163:27:00	45	292:14:00




# 2015 Cryo availability (Cryo Maintain)



164 losses

Total down time = 273 h 29 min



## The most time consuming losses:

PLC: 4 failures with 26.9%

⇒ solved during YETS'15

Cold compressor: 8 failures 19.4 %

⇒ solved during Technical Stops

Human factor 15.1% (mainly late TS1 recovery)

Elec. Instrum. Tunnel 13.3 %

4 above contributors:  
→ 75% of the down time

## The most frequent losses (main contributors):



Electrical feed boxes He level (60 losses)

⇒ solved during YETS'15 with QSRB-8 repair (SHe of better quality) + adaptation of operational thresholds and fine tuning of controllers

NB: YETS = Year End Technical Stop

# 2016 Cryo availability (Cryo Maintain)




	Total	CRYO-TUNNEL-INSTRUM	CRYO-OP-PNO-SAM	CRYO-OP-PNO-HF	CRYO-PROD-1.8K	CRYO-PROD-PLC	CRYO-OP-PNO-DFB
Number	16	3	2	2	2	1	6
Duration	73:21:00	9:19:00	0:10:00	16:13:00	21:31:00	22:50:00	3:18:00



2016 RUN 2 CRYO Availability Summary	
Due Operation Time	4813:21:00
Cryo losses	1.5%
Total Cryo Downtime	73:21:00
<b>Cryo Availability for 8 sectors</b>	<b>98.5%</b>
Delayed injections	22:21:13
<b>Cryo Availability counting delays</b>	<b>98.0%</b>


# LHC HELIUM INVENTORY MANAGEMENT

# LHC helium inventory storage




# LHC helium inventory management

150 metric tons of helium




# Typical helium inventory follow-up

Inventory on	04/03/2016	149.9 tons
Trailers received	5 trailers	21.4 tons
Deliveries to Experiences & Test Facilities		-13.4 tons
Identified accidental losses		-1.9 tons
Recurrent losses		-6.5 tons
Inventory on	18/10/2016	149.6 tons




### 2016 Total Recurrent He Losses Evolution





# Helium consumptions and losses



# Main actions

**Our main goal:** reduce our recurrent He losses and improve the precision of our balance.

## How ?

- Look for He losses in ventilation: surface installations check regularly, tunnel installations to be done during next Technical Stop and Extended Year End Technical Stop – *in progress*
- Systematic check of gaseous storage installations (as it is one of the major contributors to our recurrent losses)
- On-line follow-up accuracy checks – improvements
- Operational consumptions accounting: around 500 kg of He per year for the whole machine regarding adsorbers and dryers regenerations – shall be extracted from our recurrent losses – *in progress*

# Conclusions and perspectives

- Experience from RUN 1 allowed for maintaining high level of availability as well as reducing helium losses
- Large LS1 campaign permitted to solve all RUN 1 non-conformities to restart with highly reliable and consolidated hardware for RUN 2
- Extensive follow-up of the origins of the downtime allowed for proposing adequate mitigation solutions to encountered problems, thus improving our hardware reliability and finally our availability
- Some room available for ongoing improvements regarding hardware reliability and helium inventory accountability

**THANK YOU !**



[www.cern.ch](http://www.cern.ch)