

# Beam Dump Facility (BDF) at CERN – Radiological and environmental assessment


H. Vincke, C. Ahdida, M. Casolino, S. Roesler, P. Avigni, J. Busom, M. Calviani, J.P. Canhoto Espadal, J-L. Grenard, R. Jacobsson, K. Kershaw, M. Lamont, E. Lopez Sola **on behalf of the BDF project**

# Outline

- BDF concept and requirements
- General RP considerations
- RP evaluation for the BDF target complex
  - Prompt and residual dose
  - Air and He activation
  - Radioactive waste
- Summary & conclusion

# BDF requirements

## Layout of BDF and surrounding facilities



More details about target and facility in talks from Lopez Sola, Kershaw and Lamont

BDF is a proposed permanent facility in the North Area at CERN

- High intensity proton beam:  **$4 \cdot 10^{13}$  p<sup>+</sup>/pulse, 355 kW average beam power,  $2 \cdot 10^{20}$  pot/5 years**  
→ RP constraints on design due to prompt/residual dose
- Location close to experimental and public areas  
→ **Minimize impact on other facilities and environment**
- Dense TZM and W target  
→ **High activation expected**
- Keep **flexibility for future installations**  
→ Ventilation system  
→ Dismantling and waste treatment


### Key BDF beam parameters

Momentum [GeV/c]	400
SPS beam Intensity per cycle [ $10^{13}$ ]	4.0
Cycle length [s]	7.2
Spill duration [s]	1
Avg. beam power on target [kW]	355
Avg. beam power on target during spill [kW]	2500
Protons on target (POT)/year	$4 \cdot 10^{19}$
Total POT in 5 year's data taking	$2 \cdot 10^{20}$


# BDF target complex

- Target is located 15 meters underground
- Iron hadron absorber encloses production target
- Target and hadron absorber are inside a He vessel
- Fully remote handling/manipulation
- Significant attention to radiation protection
- Crane and trolley concepts → equivalent shielding, but target handling safer with trolley


## Crane concept overview



## Target and hadron absorber




## Trolley concept overview



# General considerations for the BDF target complex


- **High prompt dose** in BDF target area calls for adequate shielding around the target
- **Only absolute necessary equipment** should be installed in “hot” areas
- Depending on residual dose rate and tasks, **manual interventions** should partially/completely be **replaced by remote maintenance/repair**
- **Water cooling circuits** for highly radioactive elements should be **closed and separated** from others
- **Activation and contamination** of ground water and earth to be **avoided**



- **Air volumes** to be **minimized** in ‘hot’ areas or to be **replaced by He/vacuum** environment
- **Static confinement** of air by physical barriers to separate air in contaminated areas from outside
- **Dynamic confinement** by a ventilation system guaranteeing a pressure cascade from low to high contaminated areas
- The design must consider minimization, decommissioning and dismantling of radioactive waste

# RP evaluation based on FLUKA simulations


## BDF/SHiP as implemented in FLUKA - Side view




- **No access during operation** into the detector hall is the main condition for current design
- **Massive shielding** to keep prompt/residual dose rate and airborne **radioactivity as low as possible**
- Active muon shield with magnets (1.8 T) from the SHiP experiment was included

# RP evaluation based on FLUKA simulations

## BDF/SHiP as implemented in FLUKA - Cross-sectional view




- Most critical area was embedded in He-environment
- Shielding was optimized to reduce ground activation around the BDF target station to negligible levels
- Accurate material compositions were used (AISI316LN w 0.1% Cobalt, ASTM A48 w 0.04% Cobalt, US1010, CENF moraine, ...)






# Expected dose rates in the target area



## Prompt dose rate at $4 \times 10^{13}$ p / 7.2s




**Prompt dose rates** reach **~10 - 100 mSv/h** above He-vessel and drop down to **< 1  $\mu$ Sv/h** above top concrete shielding (conservative gaps 5 cm)

→ Expected classification: **Supervised Radiation Area** (up to 2000h/year) (**< 3  $\mu$ Sv/h**) in the target hall

100 rem = 1Sv

## Residual dose rate at $2 \times 10^{20}$ pot (1 week cooling)




**Residual dose rates** of a few  **$\mu$ Sv/h** above and next to He-vessel

**Very high residual dose rates** next to target and cast iron shielding **O(100) Sv/h**

→ **Remote handling** and designated storage areas are therefore foreseen for these elements


# Expected dose rates in the experimental area

**Prompt dose rate at  $4 \times 10^{13}$  p / 7.2s**



**Prompt dose rates** reach  $\sim 100$  mSv/h at magnet mainly due to muons

**Residual dose rate at  $2 \times 10^{20}$  pot (1 week cooling)**




**Residual dose rates** close to first part of muon shield reach  $\sim 10$   $\mu$ Sv/h

→ Expected classification: **Supervised Radiation Area ( $< 15$   $\mu$ Sv/h)** in experimental hall

$100 \text{ rem} = 1 \text{ Sv}$

# Expected dose rates in the surrounding area



## Muon prompt dose rate at $4 \times 10^{13}$ p / 7.2s




Muon prompt dose above experimental hall  
~50  $\mu$ Sv/h

→ Need to cover area with at least 3m of soil on top to allow for non-designated area level (<0.5  $\mu$ Sv/h)

100 rem = 1Sv



Muon prompt dose around existing facilities both underground and above-ground below non-designated area level (<0.5  $\mu$ Sv/h)



# Classification of the ventilation system

- Ventilation system requirements inspired by **ISO 17873:2004**
- Four possible classifications:

Classification	Depression values	DAC <sup>1</sup> values permanent (accident)
C1	<60 Pa	0 (<1)
C2	80 to 100 Pa	<1 (<80)
C3	120 to 140 Pa	<1 (<4000)
C4	220 to 300 Pa	>1 (any)


## ISO 17873:2004:

Nuclear facilities — Criteria for the design and operation of ventilation systems for nuclear installations other than nuclear reactors

- Normal operation DAC < 1
- Accident case analysed → **He vessel breakdown**
  - **99.9% He purity** from He purification system → assumed 0.1% air contamination
  - DAC values calculated mixing He and air of closed loop
  - **DAC for accident ~ 2.7**
  - **Inhaled dose 8 μSv** in ~1 hour in case of accident
- Classification for ventilation system: **C2**
  - For flexibility for future installations could be classified as **C3**
  - Defined pressure differences between compartments to have dynamic confinement

<sup>1</sup>DAC ... Derived Air Concentration.

# Classification of the ventilation system



# Radiological impact of releases

- Identified 6 reference groups around new BDF target facility
- Parameters of ventilation stack not yet defined
  - Conservative approach: ground release

	Workers waste treatment center	North-East	North-West	West	South-East	Agriculture
Received dose [nSv/year]	0.07	0.3	0.5	0.5	0.08	0.1

→ negligible doses

# Tritium production


H-3 has very low radio-toxicity however can be a radiation hazard when:

- inhaled
- ingested via food or water
- absorbed through the skin

A simplified geometry was used:

- Target: 1 section of Mo, 1 section of W, no water cooling, no Ta cladding
- Region between target and proximity shielding filled by He
- Proximity shielding and passive shielding in Cast Iron
- 2 m concrete thick walls around passive shielding

## Simplified FLUKA geometry





# Tritium production and out-diffusion

## H-3 production for different materials


10 TBq = 270 Ci

Material	H-3 activity
Mo	10 TBq
W	8 TBq
He	0.9 GBq
Cast Iron	1 TBq
Concrete	2 MBq

**5 years of operation**  
→  **$2 \cdot 10^{20}$  pot**


- 95% of H-3 produced in the target
- H-3 can be absorbed by target cooling water (HTO form)
- For iron and concrete shielding H-3 outgassing contributes to air contamination even during no beam periods

In order to better quantify the 'out-diffusion' of H-3 we will add samples of **Tungsten, Tantalum, TZM, Cast Iron and Concrete** to the BDF target prototype being irradiated in Sep/Oct 2018 at CERN **and** measure the out-diffusion of H-3.



# Radioactive waste production

- Calculations performed assuming **5 years operation** →  $2 * 10^{20}$  pot
- Results presented in terms of Design Limits (DL)  
→ If **DL > 1** the material/waste is radioactive
- Floor below the target slightly radioactive, increase iron thickness in the helium vessel to leave the facility 'clean' for future installations




$$DL = \sum_{i=1}^n \frac{a_i}{LL_i}$$

a ... specific activity,  
LL .. 'clearance' limit

# Summary & conclusion

- The proposed BDF would be a **new permanent facility in the North Area** with unprecedented average beam power
- An in-depth study of the proposed BDF at CERN's is underway.
  - Target design needed careful studies and R&D
  - Target area particularly critical – embedded in a Helium vessel
  - High prompt & residual dose rates → massive shielding and remote interventions
- The design is based on significant experience at CERN with such facilities (WANF, CNGS, etc.)
- The BDF project team aims to produce a comprehensive design study by end 2018 ... as input for the next update of the European Strategy for Particle Physics (ESPP).




Thank you for your attention!

# Air activation

- Calculations performed assuming **5 years operation** →  $2 * 10^{20}$  pot
- **99.9% He purity** from He purification system → assumed **0.1% air contamination**
- For the CA<sup>1</sup> calculation:
  - Assumed a standard breathing rate (1.2 m<sup>3</sup>/h)
  - For the moment no leakage term

<sup>1</sup> Person working 40h/w, 50w/y with standard breathing rate in air contaminated environment with CA = 1 receives 20 mSv.



	Activity (Bq) after 60 s cooling	Multiple of CA
● Air in inner He volume	$5.6 * 10^7$	$7.5 * 10^5$
● Air in middle He volume	$7.8 * 10^5$	$1.3 * 10^3$
● Air in external He volume	$1.5 * 10^2$	$2 * 10^{-2}$
● First air volume	$1.7 * 10^7$	0.7
● Second air volume	$8.3 * 10^4$	$6.7 * 10^{-3}$
● Inner He volume	$2.8 * 10^9$	0.42
● Middle He volume	$4.1 * 10^7$	$8.7 * 10^{-4}$
● External He volume	$9 * 10^3$	$1.5 * 10^{-8}$

# Tritium out-diffusion

- Assumption of an immediate **release efficiency of 100%** can be **over-conservative**
  - Tritium releases were measured years after the shutdown of CERN facilities (e.g. CNGS)
- Diffusion equation **has to be solved for arbitrary geometries**
  - A newly coded **plug-in for FLUKA [1]** solves diffusion equation using a Monte Carlo approach
  - It transports nuclides using a stochastic approach in the continuous limit
- In literature **diffusion coefficients** for tritium are **available only for few materials** and not in the full temperature range
  - Arrhenius equation used to extrapolate to operational temperatures
- Study of feasibility to **measure out-diffusion of tritium** from Tungsten, Tantalum, TZM, Cast Iron and Concrete
  - Possibility to measure diffusion constants
- **Simulated out-diffusion @298K (@423K)** from **Iron** shielding after 2 months is about **33%** (38%), while from **Tungsten** is **0.18%** (2.43%)

[1] Development of a computational model for the out-diffusion of radioisotopes from metals, C.Theis and H.Vincke, CERN-RP-2016-173-REPORTS-TN

# Search for Hidden Particles (SHiP) at BDF



SHiP is aimed at exploring the domain of hidden particles and make tau neutrino measurements

<http://ship.web.cern.ch/ship/>

**“Zero background” experiment**


- Muon shield
- Surrounding Veto detectors

$>10^{18} D, >10^{16} \tau, >10^{20} \gamma$   
for  $2 \times 10^{20}$  pot (in 5 years)



Tracker  
Spectrometer  
Particle ID

Decay vessel



**Search for Hidden Sector particles (decays in the decay volume)**

$\nu_\tau$  physics (specific event topology). Search for DM (scattering on atoms)