



WBS 121.5 – Conventional Facilities

Design and Scope

Steve Dixon

PIP-II DOE Independent Project Review

12-14 December 2017

In partnership with:

India/DAE

Italy/INFN

UK/STFC

France/CEA/Irfu, CNRS/IN2P3


Charge Questions

Charge Question	Presentation
1. Has the project team documented a carefully considered analysis of alternates that supports the preferred alternate?	Plenary and Design and Scope Breakout
2. Does the conceptual design satisfy the performance requirements?	Design and Scope Breakout
3. Does the conceptual design report and supporting documentaton adequately justify the stated cost range and project duration?	Cost and Schedule Breakout
4. Does the project team have adequate management experience, design skills, and laboratory support to manage all aspects of this project and produce a credible technical, cost, and schedule baseline?	Management Breakout
5. Are the ES&H aspects of the project being properly addressed and is the ES&H planning currently sufficient for this stage of the project?	Plenary
6. Is the documentation required by DOE O413.b for CD-1 approval complete and in good order?	CD-1 Documentation Breakout
7. Is the allocation of the technical scope that will be contributed by international partners sufficiently understood and documented such that the conceptual design and cost range can be relied on?	Plenary
8. Has the project satisfactorily responded to the recommendations from previous reviews?	Plenary

Agenda

- Conceptual Design Process
- Alternates Investigated
 - Siting
 - ICW Cooling
 - Pulsed Mode vs. Continuous Wave Operation
- Next Steps

Conventional Facilities Overview



Work Breakdown Structure

- 121.5.2 Site Preparation
- 121.5.3 Cryo Plant Building
- 121.5.4 Utility Plant Building
- 121.5.5 High Bay Building
- 121.5.6 Linac Tunnel
- 121.5.7 Linac Gallery
- 121.5.8 Beam Transfer Line
- 121.5.9 Booster Connection

Conventional Facilities Overview



Looking Southeast From Wilson Hall







White Flags = Warm Components
Blue Flags = Cold Components

Looking South Along Beamline



View from Wilson Hall

Process

- Functional Requirements Specification (Project Level)

- Functional Requirements Specification (Subproject Level)

- Conceptual Design
 - Drawings [1]
 - Text [2]
 - Estimate Assumptions [3]
- Technical Requirements Specifications

- **Cost/Schedule Estimate** (Separate Breakout Presentation)

[1] – Conceptual Design Drawings can be found in PIP-II-doc-1155

[2] – Conceptual Design Report can be found at PIP-II-doc-113

[3] – Estimate Assumptions can be found at PIP-II-doc-333, Item D

PIP-II Functional Requirements Specifications

- “PIP-II is focused on upgrades to the Fermilab accelerator complex capable of providing proton beam power in excess of 1 MW on target at the initiation of the Long Baseline Neutrino Facility/Deep Underground Neutrino Experiment (LBNF/DUNE) program, currently anticipated for the mid-2020s”
- TeamCenter document ED0001222, signed in March 2017 (PIP-II-doc-1166)

Integration and Upgradability

Requirement	Description	Value
I1	The siting of the PIP-II facility will be consistent with future replacement of the existing 8-GeV Booster with either an 8 GeV Rapid Cycling Synchrotron or superconducting pulsed linac	
I2	The siting of the PIP-II facility will be consistent with future upgrades to provide 100 kW beams to the Mu2e hall on the Muon Campus	
I3	The SC Linac will be constructed of components capable of operating in CW mode, following modest upgrades	
I4	The SC Linac will be constructed in a manner that allows installation and commissioning without interruption to ongoing accelerator operations	
I5	Residual Activation from Uncontrolled Beam Loss in areas requiring hands-on maintenance.	<20 mrem/hour (average) <100 mrem/hour (peak) @ 1 ft
I6	Scheduled Maintenance Weeks/Year	8
I7	SC Linac Operational Reliability	90%
I8	60-120 GeV Operational Reliability	85%
I9	Facility Lifetime	≥40 years

Conventional Facilities
specific requirements

Conventional Facilities FRS and TRS

- Functional Requirements Specification (FRS) define the function of each component (**what**);
- Technical Requirements Specification (TRS) define the critical technical requirements for each components (**how**);
- Support the PIP-II Project FRS;
- Developed for each conventional facilities work package;
- Ensures design meets the requirements;

WBS	Identification	Functional Requirements Specification	Technical Requirements Specification
		TeamCenter	TeamCenter
121.5.1	CF Project Management and Coordination		
121.5.2	Site Preparation	ED0006787	ED0006789
121.5.3	Cryo Plant Building	ED0006718	ED0006719
121.5.4	Utility Plant Building	ED0006748	ED0006749
121.5.5	High Bay Building	ED0006756	ED0006757
121.5.6	Linac Tunnel	ED0006790	ED0006791
121.5.7	Linac Gallery	ED0007079	ED0006793
121.5.8	Beam Transfer Line	ED0006785	ED0006786
121.5.9	Booster Connection	ED0006794	ED0006795

Typical FRS

Section 1 – Conventional Facilities Purpose

The PIP-II conventional facilities will house the accelerator components and support equipment required to install and operate the PIP-II linac and transfer line. The PIP-II conventional facilities scope includes the elements of work normally included in conventional construction such as earthwork, utilities, structural concrete, structural steel, architectural cladding, finishes, roofing, plumbing, process piping, heating ventilation and air conditioning (HVAC), fire protection, fire detection, lighting and electrical. This also includes the work required to extend the utilities to the project site, excavation associated with the below grade cast-in-place concrete enclosures, creation of a shielding berm and site restoration.

Section 2 – Key Assumptions

Assumptions related to the Cryogenics Plant Building are contained in the Assumptions Document (TeamCenter ED0001222)

Section 3 – Functional Requirements

The function of the Cryogenics Plant Building is to house the processes required to install, assemble and operate the cryogenic plant and related spaces to support PIP-II accelerator operations.

The function of the Cryogenics Plant Building is to house the processes required to install, assemble and operate the cryogenic plant and related spaces to support PIP-II accelerator operations.

Typical TRS Contents

Technical Requirements Specifications

Cryo Plant Building

WBS 121.5.3

Table of Contents

1. Conventional Facilities Purpose
2. Scope
3. Requirements
 1. Spatial Requirements
 2. Architectural Requirements
 3. Structural Requirements
 4. Mechanical Requirements
 5. Electrical Requirements
 6. Fire Protection Requirements
 7. Special Requirements
4. Code Requirements
 1. Organizational Processes
 2. Enterprise Standards

Typical Technical Requirements Specification Table of Contents

Typical TRS

Section 1 – Conventional Facilities Purpose

The PIP-II conventional facilities will house the accelerator components and support equipment required to install and operate the PIP-II linac and transfer line. The PIP-II conventional facilities scope includes the elements of work normally included in conventional construction such as earthwork, utilities, structural concrete, structural steel, architectural cladding, finishes, roofing, plumbing, process piping, heating ventilation and air conditioning (HVAC), fire protection, fire detection, lighting and electrical. This also includes the work required to extend the utilities to the project site, excavation associated with the below grade cast-in-place concrete enclosures, creation of a shielding berm and site restoration.

Section 2 – Scope

The Cryogenics Plant Building consists of the conventional construction required to install, house and operate the cryogenics plant to support PIP-II accelerator operations. The cryogenics equipment, installation, assembly, testing and commissioning will be accomplished by others.

Section 3 – Requirements

3.1 – Spatial Requirements

The Cryogenics Plant Building will be located at the downstream end of the Linac Enclosure in order to be positioned to allow for future expansion.

The Cryogenics Plant Building contains three (3) primary spaces as described below:

Cold Box Station - The Cold Box Station will contain the equipment to install, operate and maintain the cold box. This includes the following requirements:

- Building Size: 15 m x 40 m (50 feet x 131 feet);
- Overhead door 5 m x 5 m (17 feet x 17 feet);
- Space for five (5) 10,000 liter (2,641 gallons) dewars;
- Coordination Center to house 4-8 people;
- Control Room to accommodate equipment, monitors and related control equipment;
- Control Room and Coordination Center should have an isolated HVAC system that is capable of pressuring the room to reduce the oxygen deficiency hazard of the space;

Warm Compressor Station - The Warm Compressor Station will contain the equipment to install, operate and maintain the compressors and related equipment to support the Cold Box Station. This includes the following requirements:

- Building Size: 20 m x 30 m (66 feet x 100 feet)
- Overhead door 5 m x 5 m (17 feet x 17 feet);
- Space for five (5) 10,000 liter (2,641 gallons) dewars;

Exterior Space - The exterior space for the Cryogenics Plant Building will provide for access to the Cold Box Station and Warm Compressor Station. This includes the following requirements:

- Space for ten (10) 113,000 liter (30,000 gallon) storage tanks and related piping;

The Cryogenics Plant Building contains three (3) primary spaces as described below:

Cold Box Station - The Cold Box Station will contain the equipment to install, operate and maintain the cold box. This includes the following requirements:

- Building Size: 15 m x 40 m (50 feet x 131 feet);
- Overhead door 5 m x 5 m (17 feet x 17 feet);
- Space for five (5) 10,000 liter (2,641 gallons) dewars;
- Coordination Center to house 4-8 people;
- Control Room to accommodate equipment, monitors and related control equipment;
- Control Room and Coordination Center should have an isolated HVAC system that is capable of pressuring the room to reduce the oxygen deficiency hazard of the space;

Warm Compressor Station - The Warm Compressor Station will contain the equipment to install, operate and maintain the compressors and related equipment to support the Cold Box Station. This includes the following requirements:

- Building Size: 20 m x 30 m (66 feet x 100 feet)
- Overhead door 5 m x 5 m (17 feet x 17 feet);
- Space for five (5) 10,000 liter (2,641 gallons) dewars;

Conceptual Design Process

- Meetings with Stakeholders:
 - Goal: Document the spatial and infrastructure requirements for PIP-II facilities; [4]
 - Started in January 2016;
- Results:
 - Conceptual Design drawings and text that described the sizes/arrangement of spaces and buildings to accommodate the functional requirements; [5]
 - Cost Estimate Assumptions; [6]
 - Life Safety Analysis; [7]
 - Cooling strategies for pulsed mode and continuous wave operation;
 - **Conventional facilities are similar to typical Fermilab construction;**

[4] – Meeting Minutes can be found in PIP-II-doc-70

[5] – Conceptual Design Drawings can be found in PIP-II-doc-1155

[6] – Assumptions can be found at PIP-II-doc-333

[7] – Final LSA can be found at PIP-II-doc-120

Conceptual Design Process

Stakeholders:

Fermilab:

Alessandro Vivoli, Anindya Chakravarty, Anthony F Leveling, Arkadiy L Klebaner
Beau F. Harrison, Curtis M. Baffes, David E Johnson, David W Peterson
Don Cossairt, Donald V Mitchell, Emil Huedem, Jim Niehoff, Fernanda G Garcia
Jerry R Leibfritz, Jerzy Czajkowski, John E Anderson Jr, Luisella Lari
Matthew Quinn, Maurice Ball, Paul Derwent, Ralph J Pasquinelli
Todd M Sullivan, Valeri A Lebedev, William A Pellico

Consultants:

Tom Lackowski, TGRWA
Ron Jedziniak, LG Associates
Rick Glenn, Jensen Hughes

Meeting Minutes (PIP-II-doc-70)

- [01 - Coordination Meeting - 17FEB16 \(pdf\)](#)
- [02 - Cryogenic Department Meeting 19FEB16 \(pdf\)](#) – Cryo Meeting
- [03 - Coordination Meeting - 02MAR16 \(pdf\)](#) – Linac Enclosure
- [04 - Coordination Meeting - 09MAR16 R1 \(pdf\)](#) – Linac Enclosure and Cooling
- [05 - Coordination Meeting - 24MAR16 R1 \(pdf\)](#) – Linac Enclosure and Cryo Plant
- [06 - Cryo Coordination Meeting - 01APR16 \(pdf\)](#) – ICW Cooling and Cryo
- [07 - Coordination Meeting - 14APR16 \(pdf\)](#) – Penetrations and Cooling Strategy
- [08 - Coordination Meeting - 28APR16 \(pdf\)](#) – Cooling Strategy
- [09 - Coordination Meeting r1 - 12MAY16 \(pdf\)](#) – Shielding and Transport Line
- [10 - Coordination Meeting - 09JUN16 \(pdf\)](#) – Shielding Summary
- [11 - Coordination Meeting - 07JUL16 \(pdf\)](#) – RF Distribution and LCW Cooling
- [12 - Coordination Meeting - 21JUL16 \(pdf\)](#) – High Bay Equipment
- [13 - Coordination Meeting - 04AUG16 \(pdf\)](#) – Cryo Summary and Linac Gallery
- [14 - Coordination Meeting - 15SEP16 \(pdf\)](#) – Sitewide Electrical Distribution

Drawings (PIP-II-doc-1155)

55 Drawings

- One (1) General sheet
- Seven (7) Civil sheets
- Forty-Three (43) Architectural sheets
- Three (3) Mechanical sheets
- One (1) Electrical sheet

LIST OF DRAWINGS

G-1 TITLE SHEET, LIST OF DRAWINGS

C-1 SITE IMAGE

C-2 FUTURE BEAMLINES SITE PLAN

C-3 WETLANDS SITE PLAN

C-4 SITE PLAN

C-5 ENLARGED PLAN AT ABSORBER

C-6 SITE UTILITY PLAN

A-1 DESIGN BASIS - SHEET 1

A-2 DESIGN BASIS - SHEET 2

A-3 DESIGN BASIS - SHEET 3

A-4 LIFE SAFETY

A-5 ENCLOSURE KEY PLAN

A-6 LINAC ENCLOSURE PLAN - SHEET 1

A-7 LINAC ENCLOSURE PLAN - SHEET 2

A-8 LINAC ENCLOSURE PLAN - SHEET 3

A-9 LINAC ENCLOSURE PLAN - SHEET 4

A-10 TRANSPORT ENCLOSURE PLAN - SHEET 1

A-11 TRANSPORT ENCLOSURE PLAN - SHEET 2

A-12 TRANSPORT ENCLOSURE PLAN - SHEET 3

A-13 TRANSPORT ENCLOSURE PLAN - SHEET 4

A-14 TRANSPORT ENCLOSURE PLAN - SHEET 5

A-15 TYP. LINAC ENCLOSURE SECTION

A-16 TYP. TRANSPORT ENCLOSURE SECTION

A-17 ELEVATION AT MAIN RING CROSSING

A-18 PIP II CAMPUS PLAN

A-19 LINAC SUPPORT BUILDING KEY PLAN

A-20 LINAC SUPPORT BUILDING PLAN - SHEET 1

A-21 LINAC SUPPORT BUILDING PLAN - SHEET 2

A-22 LINAC SUPPORT BUILDING PLAN - SHEET 3

A-23 LINAC SUPPORT BUILDING PLAN - SHEET 4

A-24 LINAC SUPPORT BUILDING PLAN - SHEET 5

A-25 SOUTHEAST BOOSTER BUILDING - DEMO PLAN

A-26 SOUTHEAST BOOSTER BLDG. - EXCAVATION PLAN

A-27 SOUTHEAST BOOSTER BUILDING - PLAN

A-28 SECTION THRU RECEIVING

A-29

A-30

A-31

A-32

A-33

A-34

A-35

A-36

A-37

A-38

A-39

A-40

A-41

A-42

A-43

CROSS SECTION THRU HIGH BAY

CROSS SECTION @ HWR

SECTION THRU HIGH BAY

SECTION @ COAX FOR SSR1, SSR2

SECTION @ WAVEGUIDE FOR LB 650, HB 650

SECTION AT LINAC ALCOVES

SECTION SHEET - 1

SECTION SHEET - 2

SECTION SHEET - 3

SECTION SHEET - 4

SECTION SHEET - 5

CRYOGENIC PLANT

COLD BOX STATION PLAN

COMPRESSOR STATION PLAN

PIP II UTILITY PLANT PLAN

M-1 CONCEPTUAL DESIGN BASIS - SHEET 1


M-2 CONCEPTUAL DESIGN BASIS - SHEET 2

M-3 COOLING HEAT REJECTION CONCEPT

E-1 POWER SINGLE LINE DIAGRAM

Typical Design Basis Sheet

Base Design: Eliminates this portion of the Linac Gallery (included as an Additive Alternate)



PROTON IMPROVEMENT PLAN - II
DESIGN BASIS - SHEET 3

LINAC SUPPORT BUILDING

FUNCTIONAL AREAS:
 HIGH BAY / RECEIVING: MATERIAL ENTRY, MATERIAL HANDLING, MATERIAL STAGING AND STORAGE (NORMALLY OCCUPIED)
 SIDE BAY: ESCORTED PUBLIC ENTRY, OPERATIONS SUPPORT INCLUDING TECH. SPACE, CONTROL ROOM, MEETING ROOM, TOILETS AND BUILDING UTILITIES (NORMALLY OCCUPIED)
 GALLERY: HOUSES AMPS, RACKS FOR CRYOMODULE CONTROL AND SUPPORT, MAGNET POWER SUPPLIES
 NON PROTECTED EXPOSED STEEL TYPE II B PER IBC.
 PER ASHRAE 90.1 & HPSB GUIDING PRINCIPLES
 OVERHEAD ROLL UP DOORS
 20 TON OVERHEAD CRANE IN HIGH BAY, 1 TON MONORAIL HOISTS IN GALLERY

CONSTRUCTION:
 U-VALUES:
 EQUIPMENT ACCESS:
 EQUIPMENT HANDLING:

OCCUPANT LOAD:
 30-50 PERSONS DURING INSTALLATION, 10-20 PERSONS DURING MAINTENANCE, 6-8 PERSONS DURING NORMAL OPERATIONS

HVAC:
 HIGH BAY AND SIDE BAY: 78 MAX SUMMER, 68MIN. WINTER, NO HUMIDITY CONTROL, GALLERY 80 MAX, 65M MIN., NO HUMIDITY CONTROL. CONTROL ROOM POS. PRESSURE TO SURROUNDING AREAS.

PURGE VENTILATION:
 2 ACH (HIGH BAY ONLY)


OCCUPANT VENTILATION:
 LCW:
 CHILLED WATER:
 ICW:
 TECH POWER:

LIGHTING:
 EMERGENCY LIGHTING:
 EXIST SIGNS:
 CONV RECEP:
 WELDING RECEP:
 EGRESS:
 SPECIAL:
 FIRE DETECTION:
 FIRE NOTIFICATION:
 FIRE SUPPRESSION:

PER ASHRAE 62.1
 ALL BURIED PIPE BY CONVENTIONAL COST. DISTRIBUTION BY OTHER WBS FOR HVAC, ION SOURCE AND RFQ VANE
 FIRE PROTECTION
 480V DISTRIBUTION TO 800 OR 1200 AMP POWER PANELS, 120/208V DISTRIBUTION TO 400 AMP POWER PANELS; MAJOR LOADS SHOWN ON PLAN ABOVE
 65FC cONTROLLED VIA LIGHTING PANEL
 PER NFPA 101 LIFE SAFETY CODE
 PER NFPA 101 LIFE SAFETY CODE
 120 / 208 V AC
 (QTY 2 IN GALLERY) 480V
 MAXIMUM TRAVEL DISTANCE 250-FT TO EXIT
 ADMINISTRATION CONTROL ACCESS PROVIDED
 MANUAL PULL STATIONS AT EXITS
 AUDIBLE AND VISUAL DEVICES THROUGHOUT
 AUTOMATIC SPRINKLER SYSTEM DESIGNED TO ORDINARY HAZARD GROUP II - HIGH TEMPERATURE SPRINKLERS


DATE: 28 OCT. 2016
 PROJECT NO: 4-2-3
 DRAWING NO: A-3

Typical Linac Tunnel Cross Section




Cryomodule criteria envelope (TeamCenter F10051442)

Typical Linac Tunnel Cross Section




Linac Tunnel Plan (WBS 121.5.6)



Plan at Enclosure Level

FRS Section 5 (Facility Scope):
The linac enclosure will be constructed with a length to accommodate two (2) HB650 cryomodules beyond the nominal compliment required for 800 MeV


Preliminary Shielding Considerations



Preliminary Shielding Depths shown below. **Further analysis required**, especially at the Booster.



Used the 10W/m curve for the conceptual design

18.5'
(transport line and absorber)




Thanks to Radiation Safety Department (D. Cossairt, T. Leveling and M. Quinn)

Linac Gallery Plan (WBS 121.5.7)




Cross Section Looking South at Waveguide Penetrations




Cross Section Looking South at Coax Penetrations

Beam Transfer Line (WBS 121.5.8)

FRS Integration and Upgradability:
 12: *The siting of the PIP-II facility will be consistent with future upgrades to provide 100 kW beams to the Mu2e hall on the Muon Campus*




Booster Connection (WBS 121.5.9)




Looking Northeast Towards Booster Tower Southeast

FRS Integration and Upgradability:
 14: *The SC Linac will be constructed in a manner that allows installation and commissioning without interruption to ongoing accelerator operations*


Cryo Plant Building (WBS 121.5.3)




Utility Plant Building (WBS 121.5.4)



Cooling Concept




Electrical Distribution Concept



Alternates Considered



- Siting
- ICW Cooling
- Pulsed Mode vs. Continuous Wave Operation

Preconceptual Location



2014 Location


Siting Considerations



Existing Utilities and Services

- FRS Integration and Upgradability:**
- I1: Future RCS or Pulsed Linac
 - I2: Future 100 kW beam to Mu2e;
 - I4: Installation/Commissioning during ongoing operations
- FRS Section 5 (Facility Scope):**
- Linac length to accommodate two (2) additional HB650 cryomodules

December 2016 Siting Alternatives Study




8 GeV Tangent Option


Northward Shift Option

See PIP-II-doc-136 for Siting Alternatives Memo

Cryo Plant Cooling Water



COLD BOX STATION
 FUNCTION: HOUSE REFRIGERATOR, CONTROL ROOM, TECH. SPACE
 CONSTRUCTION: NON PROTECTED EXPOSED STEEL TYPE II B PER IBC
 U-VALUES: ASHRAE 90.1
 EQUIPMENT ACCESS: 18' W X 18' H ROLL UP DOORS
 EQUIPMENT HANDLING: 15 TON OVERHEAD BRIDGE CRANE
 HVAC: 68 MIN. 78 MAX., 50% MAXIMUM HUMIDITY
 MECHANICAL ROOM: 68 MIN. NO MAX.
 ODH VENTILATION: 45,000 CFM LOCATED HIGH AND 10,000 LOCATED LOW
 OCCUPANT VENTILATION: N/A
 CHILLED WATER: 150 GPM ALLOWANCE
 ICW: FIRE PROTECTION APPROX. 600 GPM
 OCCUPANT LOAD: 10-15 DURING INSTALLATION / 4-5 NORMALLY
 LIGHTING: 65FC
 EMERGENCY LIGHTING: PER NFPA 101 LIF
 EXIST SIGNS: PER NFPA 101 LIF
 CONV RECEP: 120 / 208 V AC
 WELDING RECEP: 480V 60 AMP (QTY
 EGRESS: MAXIMUM TRAVEL ADMINISTRATION
 SPECIAL: ADMINISTRATION
 EYE WASH STATIONS: 1
 EXHAUST CONTROL: ODH ABATEMENT
 FIRE DETECTION: MANUAL PULL STA
 FIRE NOTIFICATION: AUDIBLE AND VIS THROUGHOUT
 FIRE SUPPRESSION: AUTOMATIC SPRIN DESIGNED TO ORD GROUP II - HIGH T



Cryo Compressors

WARM COMPRESSOR STATION
 FUNCTION: HOUSE FOUR CRYO COMPRESSORS
 CONSTRUCTION: NON PROTECTED EXPOSED STEEL TYPE II B PER IBC
 U-VALUES: ASHRAE 90.1
 EQUIPMENT ACCESS: 18' W X 18' H OVERHEAD ROLL UP DOOR
 EQUIPMENT HANDLING: 25 TON OVERHEAD BRIDGE CRANE
 HVAC: SUMMER AMBIENT VENTILATION ONLY, NO MAXIMUM HUMIDITY
 WINTER 60F. NO MINIMUM HUMIDITY
 PURGE VENTILATION: 50,000 GPM FOR ODH CONDITION
 OCCUPANT VENTILATION: N/A
 ICW: NONE
 PROCESS COOLING: 1400 GPM PROCESS COOLING WATER 60" (PW) FOR COMPRESSORS COOLING FOR FIRE PROTECTION
 OCCUPANT LOAD: 10-15 DURING INSTALLATION / 4-5 FOR START UP AND OPERATIONS (20% OF TIME)
 LIGHTING: 65FC
 EMERGENCY LIGHTING: PER NFPA 101 LIFE SAFETY CODE
 EXIST SIGNS: PER NFPA 101 LIFE SAFETY CODE
 CONV RECEP: 120 / 208 V AC
 WELDING RECEP: 480V 60 AMP (QTY 4)
 EGRESS: MAXIMUM TRAVEL DISTANCE 250FT TO EXIT
 SPECIAL: ADMINISTRATION CONTROL ACCESS PROVIDED, EYEWASH STATIONS
 FIRE DETECTION: MANUAL PULL STATIONS AT EXITS
 FIRE NOTIFICATION: AUDIBLE AND VISUAL DEVICES THROUGHOUT
 FIRE SUPPRESSION: AUTOMATIC SPRINKLER SYSTEM DESIGNED TO ORDINARY HAZARD GROUP II - HIGH TEMPERATURE SPRINKLERS

Cryo Plant – Water Quality Requirements


		PIP-II Requirements		Water Analysis Report		Existing Data
Description	Unit	Closed loop	Open loop	Range	Units	
pH value		7.5 - 9.0	7.5 - 9.0	7.82 - 7.89		
Hardness	[dH]	< 20	< 20	20.79 - 23.02	ppm CaCO3	1 dH = 17.848 mg CaCO3
Carbonate hardness	[dH]	< 20	< 4	0.96 - 1.02	Ca/Mg ratio	
Chloride (Cl)	[mg/l]	< 100	< 100	5-15	ppm	
Dissolved iron (Fe)	[mg/l]	< 0.2	< 0.2	0.04 - 0.01	ppm	1 ppm = 1 milligram/liter
Sulphate (SO4)	[mg/l]	< 200	< 200	84.51 - 115.51	ppm	
Sulfide (S ₂)	[mg/l]	< 0.1	< 0.1			Future water analysis
Silicic acid (SiO ₂)	[mg/l]	< 200	< 200	10.63 - 11.56	ppm	Future water analysis
HCO ₃ / SO ₄	-	> 1	> 1			Future water analysis
Electrical conductivity	[μS/cm]	10 - 800	10 - 1500			Future water analysis
Ammonium (NH ₄)	[mg/l]	< 1	< 1			Future water analysis
Dissolved manganese (Mn)	[mg/l]	< 0.2	< 0.1	0.00	ppm	Future water analysis
Phosphate (PO ₄)	[mg/l]	< 15	< 15			Future water analysis
Glycol	[%]	20 - 40	-			Future water analysis
Solids (particle size)	[mm]	< 0.1	< 0.1	?	?	Requires Further Investigation
Solids (particle amount)	[mg/l]	< 10	< 10	?	?	Requires Further Investigation
Appearance		clear, colorless	clear, colorless			
Total bacterial count	[CFU/ml]	< 10 ⁴	< 10 ⁴	?	?	Requires Further Investigation
Proportion of non-dissolved solids	[ppm]	< 20	< 20	?	?	Requires Further Investigation
Algae		- not allowed	- not allowed	?	?	Requires Further Investigation
Magnesium				189.46 - 204.43	ppm CaCO3	
Calcium				181.52 - 206.42	ppm CaCO3	
Copper				0.00 - 0.01	ppm	
Total Phosphorus				0.06 - 0.13	ppm	
Zinc				0.0 - 0.01	ppm	
Sodium				23.84 - 34.98	ppm	
Molybdate				0.01 - 0.3	ppm	
Boron				0.55 - 0.65	ppm	
Aluminum				0.02 - 0.03	ppm	

Cryo Plant Cooling – Initial Analysis

- Water Requirements
 - ~**2,000** gpm flow (ideal)
- Pond System
 - Chemical characteristics met by pond water system;
 - Solids content characteristics NOT met by pond water system;
 - No Pond Exists - ~\$500-\$700k per acre;
- Industrial Cooling Water (ICW) System
 - Testing indicates that ICW meets most requirements [4];
 - Chemical characteristics met by existing ICW system;
 - Solids content characteristics NOT met by ICW system;
 - Only **1,400** gpm available per the ICW computer model;
 - Verified with Cryo that 1,400 gpm at 17 degree F delta T is acceptable

[4] – ICW Water Quality Test Results study can be found at PIP-II-doc-155

Cryo Plant Cooling – Additional Analysis



BZero Compressor Building

Summer/Fall 2016

- Test Station, installed as part of the Mu2e Cryo work for CDF;
- Installed test ports to sample the ICW before and after the strainer;
- Three Options:
 - Adams strainer with 250 micron slot sizes (baseline);
 - Two month rental of a Lakos strainer to reduce the solids with 25 micron filter;
 - Replacement filter elements in Adams strainer with 75 micron slot size;
- Arranged for FESS/O water testing service to increase the testing to include solids;
- Compared strainer options with water quality requirements.

Cryo Plant Cooling - Results

Description	Unit	PIP-II Requirements		Adam's Strainer (250 micron)		Adams Strainer (75 micron)		Lakos Filter (25 micron)		CUB Cooling Towers	
		Closed loop	Open loop	21-Oct-16		14-Dec-16		16-Nov-16		16-Nov-16	14-Dec-17
				Before	After	Before	After	Before	After		
pH value		7.5 - 9.0	7.5 - 9.0	7.51	7.71			8.28	8.23		
Hardness	[dH]	< 20	< 20	12.10	12.03			13.98	14.01		
Carbonate hardness	[dH]	< 20	< 4	1.02	1.01			1.03	1.03		
Chloride (Cl)	[mg/l]	< 100	< 100								
Dissolved iron (Fe)	[mg/l]	< 0.2	< 0.2	0.07	0.07			0.10	0.12		
Sulphate (SO ₄)	[mg/l]	< 200	< 200	36.02	34.63			46.16	44.41		
Sulfide (S ₂)	[mg/l]	< 0.1	< 0.1								
Silicic acid (SiO ₂)	[mg/l]	< 200	< 200	5.62	5.56			5.52	5.54		
HCO ₃ / SO ₄	-	> 1	> 1								
Electrical conductivity	[µS/cm]	10 - 800	10 - 1500	672.00	672.00			698.00	695.00		
Ammonium (NH ₄)	[mg/l]	< 1	< 1	0.20	0.20	---	0.30	---	0.22		
Dissolved manganese (Mn)	[mg/l]	< 0.2	< 0.1	0.01	0.01			0.01	0.01		
Phosphate (PO ₄)	[mg/l]	< 15	< 15	0.29	0.44			0.07	0.31		
Glycol	[%]	20 - 40	-	0.00	0.00			0.00	0.00		
Solids (particle size)	[mm]	< 0.1	< 0.1	---	0.04	---	0.03	---	0.03		
Solids (particle amount)	[mg/l]	< 10	< 10		see chart		see chart		see chart		
Appearance		clear, colorless	clear, colorless								
Total bacterial count	[CFU/ml]	< 10 ⁴	< 10 ⁴	1,000	1,000			0	0		
Proportion of non-dissolved solids	[ppm]	< 20	< 20								
Algae	cells/mL	- not allowed	- not allowed	986,751	1,347,557	447	47	23,785	2,144	87	13
Magnesium	ppm			107.12	106.63			122.72	122.87		
Calcium	ppm			108.86	108.13			126.81	127.12		
Copper	ppm			0.00	0.00			0.00	0.00		
Zinc	ppm			0.00	0.01			0.01	0.01		
Sodium	ppm			62.19	61.77			60.21	59.70		
Molybdate	ppm			0.01	0.00			0.00	0.01		
Boron	ppm			107.12	106.63			122.72	122.87		
Aluminum	ppm			0.03	0.03			0.04	0.04		

Results:

- Additional testing (chloride) and discussion with cryo folks;
- Algae is likely seasonal, still requires a solution or better definition of requirements;
- Baseline design will assume direct flow of ICW through cryo compressors;
- Additive Option: heat exchanger to isolate the ICW from the cryo compressor side;

Pulsed Mode vs. Continuous Wave Operation

- Driven by duty factor of the accelerator equipment
 - 15% for Pulsed Mode
 - 100% for Continuous Wave Mode
- Common For Both Modes
 - Physical arrangement of heat producing equipment;
 - Electrical power supply (not usage);
 - Conventional Facilities handles the heat load to air (HLA);
- Difference is Primarily Cooling
 - ~5.4 MW in pulsed mode;
 - ~11.76 MW in continuous wave mode;

Pulsed Mode vs. Continuous Wave Operation

Heat Loads		Pulsed Mode	Continuous Wave Mode
Low Conductivity Water (LCW)		1.65	7.07
Heat Load to Air (HLA)		0.33	1.29
Cryopant Cooling (Cryo)		3.4	3.4
Total (MW)		5.38	11.76


	Industrial Cooling Water (ICW)	Cooling Ponds (PW)	Towers (close)	Towers (open)	Basis of Estimate
Pulsed Mode	MW to GPM Conversion 682.79	MW to Acres Conversion 1.2			
	LCW 1,125 gpm	LCW 1.96 acres	LCW 1.0 towers	LCW 1.0 towers	LCW 1 towers
	HLA 227 gpm	HLA 0.50 acres	HLA towers	HLA towers	HLA chilled water via CUB
	Cryo 1,400 gpm @17 Fdt	Cryo 4.08 acres	Cryo 2.0 towers	Cryo 1.0 towers	Cryo 1,400 gpm @17 Fdt
	2,752 gpm	6.56 acres	3.00 towers	2.00 towers	Standby 1 towers
			<i>excludes standby</i>	<i>excludes standby</i>	
CW Mode	MW to GPM Conversion 682.79	MW to Acres Conversion 1.2			
	LCW 4,827 gpm	LCW 8.48 acres	LCW 4.0 towers	LCW 2.0 towers	LCW 4 towers
	HLA 881 gpm	HLA 1.94 acres	HLA 2.0 towers	HLA 1.0 towers	HLA (PM) chilled water via CUB
	Cryo 1,400 gpm @17 Fdt	Cryo 4.08 acres	Cryo 2.0 towers	Cryo 1.0 towers	HLA (CW) 2 air cooled chillers
	7,108 gpm	14.50 acres	8.00 towers	4.00 towers	Cryo 1,400 gpm @17 Fdt
			<i>excludes standby</i>	<i>excludes standby</i>	Standby 1 towers
Other Considerations	Other Considerations	Other Considerations	Other Considerations	Other Considerations	
Strainers, Drought Conditions	Strainers, Heat Exchangers, Treatment Drought Conditions	Heat Exchangers, Treatment, Make Up Building Costs	Heat Exchangers, Treatment, Make Up Building Costs	Heat Exchangers, Treatment, Make Up Building Costs	Heat Exchangers, Treatment, Make Up Building Costs

**Note: 1,400 gpm is the highest flow currently available from the existing ICW system
2,000 gpm is preferred**

Pulsed Mode vs. Continuous Wave Operation

- Goal: Modular approach that allows for efficient operation in both modes;
- CUB Chilled Water Budget: **~250 tons** total. Used for small equipment loads, building loads and RF heat load to air
- Pulsed Mode
 - Heat Load to Air (HLA): Utilize chilled water from existing CUB for equipment cooling;
 - LCW: (1) Cooling Tower + 1 standby;
 - Cryo: 1,400 gpm of ICW directly through the compressors.
- Continuous Wave Mode
 - Heat Load to Air (HLA): Install a chilled water loop to supplement the pulsed mode system with (2) air cooled chillers;
 - LCW: (3) additional Cooling Towers;
 - Cryo: No change

Pulsed Mode vs. Continuous Wave Operation



Summary

- Completed:
 - Developed a conceptual design based on technical requirements from stakeholders;
 - Investigated alternate siting locations;
 - Investigated alternate means of cooling cryo compressors;
 - Developed a modular approach to cooling during pulsed mode and continuous wave operation;
 - Approved TRS and FRS
- Next Steps:
 - Radiation Safety Assessment;
 - Refine the design during Detailed Design phase;
 - Value Engineering (purchase order in place);
 - Update the cost/schedule estimate;
 - Constructability Review at ~60%;

Questions