


Muon $g-2$ AEM Update

Brendan Kiburg, Jarek Kasper
Feb 26, 2018

Computing 1/2



- We think we understand the low efficiency problems and are working on mitigations
 - We have unpacking jobs that take the raw binary output of the DAQ and convert those data into structures compatible with our offline system (art)
 - Because we have 24 independent calorimeter data banks, we made that unpacking code multithreaded to simultaneously unpack that data.
 - The multithreaded nature is important for our many-core nearline system in order to quickly process the data for data quality checks
 - The multithreaded nature was thought to be benign for offline reconstruction on FermiGrid, perhaps offering some slight speed improvement

Computing 2/2


- What we found out with profiling tools is that the multithreaded nature is not benign on FermiGrid.
 - An unpacking jobs requests the "default" number of threads when it starts up.
 - FermiGrid is configured such that the default number of threads is the maximum number of possible threads on the node
 - Hence, there can be tens of threads that do nothing per unpacking job
 - That leads to the very poor efficiency values
 - Running those unpacking jobs single threaded will increase the efficiency greatly. We're looking into how to do that without changing our code
 - The multi-threaded version of art, when released in the next few months, will also solve this problem as we can do more things multi-threaded and keep the CPU time high

Recovery of Quad system

- Last week the quad system was deformed
 - Broken Standoffs on inner plate
 - Broken Standoffs on outer plate
 - Distortion of inner plate
- Fri 2/16, Mon 2/19, Tue 2/20
 - Assessment and planning
 - Removal of inner plate
- Wed 2/21
 - Inspection of outer foil (thinner, as beam passes through it), checked out ok.
 - Detached remaining standoffs
 - Extracted inner plate, refurbished

Recovery of Quad system

- Thurs 2/22
 - Installed new standoffs on outer plate
 - Verified alignment of outer plate at few mm level
- Fri 2/23
 - Reinstalled inner plate, verified alignment
 - Verified trolley passes
 - Secured grid and took photos
 - Visual analysis of grid permits distortion estimates
- Sat 2/24
 - Cleaning
 - Reinstalled electrical
 - Checkout @atm to 1.6 kV



Plans forward

- Mon 2/26
 - Separate team inspected cleaning
 - Sealing the Vacuum
 - Purge with dry Nitrogen
- Tue 2/27
 - Pump down and leak check
- Wed 2/28
 - Checkout to 10/15 kV after 24 hours of pumping
- Thu 3/1
 - Checkout to 14.4/20.2 kV (nominal) after 48 hours of pumping
 - Test nominal run conditions with beam

Other Systems

- Kicker refurbishment
- Exchange of dry engine in cryo plant
- Noise reduction for fiber harps
- Re-tune plunging probe
 - Ramp magnet Monday Feb 26th, calibrate center trolley probe
- Aim to re-establish beam on Wed
 - Quads below nominal
 - Timing adjustments for kickers
 - Enable upstream tuning by AD
- Aim to re-establish nominal conditions on Thu
 - Note: we were not fully running prior to quad incident
 - Some systems need to complete their tuneups with field/beam