



Ground Insulation Layout

- Minimum 2 layers everywhere.
- Minimum creep path = 7mm.
- Non-metallic key.
- Seams staggered.
- All pieces full length.
 - 1 layers on coil.
 - 2 layers on collars.

