



An Epic Tale: ICARUS Ground Short Search

Linda Bagby on behalf of the Grounding Team

(J. Brown, J. Harris, D. Torretta)

Technical Working Group Meeting

June 26, 2020

In collaboration with:





A little history---

- First started monitoring the ground 'isolation' February 9, 2019.
- The first ground short appeared April 17, 2019.
- Numerous shorts have been found and eliminated since then, with new ones developing along the way.
- On May 26, 2020 we began looking again.
- On June 19, we identified and resolved the last short.
- And this is our epic (25 step) tale.....


Successes in 'AC mode'

- With Z-mon active (AC search)
 - Clean off all unnecessary top plate equipment.
 - Perform visual inspection of experiment for mechanical short.
 - 4 cryo pipe mounting brackets
 - L-bracket mounted from building unistrut wedged between two detector referenced bits.
 - Verify cable trays are floating.
 - North to south cable trays indicated intermittent connections to building unistrut--eliminated shorts by isolating trays with tygon tubing so now trays can be grounded to the detector.



Successes in 'DC mode'

- With Detector AC power locked out
 - Install 10K resistor between cryostats and building.
 - Remove T-300 ground connections.
 - Disconnect all safety ground wires to top plate outlet boxes in the power panels
 - Vacuum system: open at 'break point'
 - Wire way: open at 'dog leg'
 - Unplug and secure all AC power cords.
- Allowed us to clear all mounting hardware of the power distribution system on the top plate.
 - Numerous intermittent shorts were resolved by replacing metal screws with non-conductive screws on the wire ways.
- Once the top plate infrastructure was cleared
 - Allowed the investigation of power panel to the Laser, Mezz racks, Strain gauge, and HV drift conduits.
 - Shorts resolved by added additional insulation material between conduits and floor grating.



Vacuum Conduit



'break point'

Wire Way




'dog leg'

And there's more....

- Once all of the Detector AC power infrastructure was cleared, we still had a 1 Ω short between the cryostat and the building.
- The area to focus on was all locations where a cryostat structure was close to a building structure.
 - Flanges with dielectric breaks are one such spot.
- Tools:
 - DMM: Measuring resistance or voltage (with an external stimulus signal connected) across the breaks and chimney locations led to the same measurement everywhere—no help.
 - Also tried increasing the measurement resolution by using the Impedance monitor readback and moving the stimulus to different areas of the experiment—still no help.
- And then came a blessing----it began with an earlier observation that the bolts on the SE condenser didn't have visible sleeves.

Magnetic Pick-Up technique

- Applied a 10kHz stimulus signal across the experiment, south end.
 - Spectrum analyzer and hand held magnetic pick-up probe scan--nothing.
 - Moved source to north end, and performed another scan with analyzer and a new tool from Joe Harris' arsenal--
- pointing to the SE condenser flange area.



Magnetic Pick-Up technique

- Using the analyzer and some keen eye balls, the magnetic field generated by the stimulus signal is measurable across 2 bolts. Hardware stack is different.



Smoking gun????

- Verified there was a sleeve—it's just long enough to cover the flange thickness.
- The external stimulus application changed the resistance from 1Ω to $.5\Omega$ so we knew we did something.....



Short cleared--

- By cleaning the carbon off of the washer and reordering the stack, the detector to building ground resistance increased from $.5\Omega$ to $11\text{k}\Omega$.
- First glance at Impedance Monitor NOT displaying 5Ω .



Short Gallery





Lesson's Learned

- Use robust isolation materials: G-10, Teflon, fiberglass unistrut, and Tygon tubing are our friends.
- Design detector AC distribution systems that are easily divisible to clear large areas at a time.
- Pay careful attention to hardware stacks on dielectric breaks.
 - An aside: Check torque on all dielectric break flange bolts after cool-down.
- Magnetic field pick-up tools are powerful.
- Do not underestimate the importance of a casual observation.


But what does it mean....

- Here's a plot from one of the monitors since last Friday.
- The vertical axis is Z (Impedance) of a 1.47kHz stimulus signal applied between the cryostat and the building grounds.
- The shorts shown were due to intermittent wire way connections and testing the system.
- We are working on correlating the fluctuations with building utilities, environmental changes, and cryo sensors.
- One thing for sure—we do not have a resistive short between the grounds.



Looking at the curve

June 20: $Z = \sim 190\Omega$, +C decreased Z, C_d : $\sim 2\mu\text{F}$



It's a new day: T0

- To maintain the 'isolation', we must be diligent and proactive.
- Everyone working on the experiment must pay attention to the alarm system.
- Installation Rules:
 - Supervisor over new installations is responsible for maintaining the 'isolation'.
 - The work plan should include the intended cable/equipment plant—includes electrical, mechanical, and cryogenic disciplines.
 - When the alarm sounds and lights blink, **immediately stop** what is being done and resolve the source of the short.
 - The system updates every 3 seconds so there is a slight delay in response.
 - Work as a collective—know where other people are working to help.
 - If the short can not be resolved easily, contact management.

Thank you to everyone for helping

- Joe Brown (Skip)
- Mike Geynisman
- Kelly Hardin
- Joe Harris
- Claudio Montanari
- Trevor Nichols
- Donatella Torretta
- Peter Wilson


A demonstration



Extras



AC Distribution



AC Distribution

