




Mod0 and 2x2 (and ND) grounding issues




SingleModule : General grounding



SingleModule : Slow Control system





SingleModule : Charge and Light R/O systems






Argon


SingleModule : LRO and CRO are connected !?





SingleModule Nov test : ground scheme (compromise)




SingleModule Nov test : ground scheme (compromise)




SingleModule Mar 21 test : Decouple LRS ground, connect at the FT





Replace brass with PAI




SingleModule Mar 21 test : ground scheme (proposed)



SingleModule HV distribution system (Detector ground)




SingleModule HV distribution system




HVPS
 $I_{\max}=1.2 \text{ mA}$
 $U_{\max}=150 \text{ kV}$




Can it be scaled up to ND (or also 2x2) ?




Ground decoupled at PFD5



Mar 2021 Test : compromise configuration



Mar 2021 Test : fallback option



Is this GND loop actually a problem?

