
ArgonCube 2x2 Installation Planning


ArgonCube 2x2 Installation Meeting on May 15, 2023

Min Jeong Kim*, Gary Smith


Interference on the top of cryostat




MPOD DC Power Cable Length Estimate for Charge/Instrumentation Readout



Preferred Module Layout







Cryostat Access Platform Details (Handrails, Gates, Step)

Rules associated with gates:

- Inward (towards the access platform) swing opening gates
- Gate width: 28" (OSHA), 22" (NFPA Life Safety Code)
- \circ Height of gate top rail: 42 ± 3 "



Cryostat Access Platform Details (Handrails, Gates, Step)



This screenshot shows

- inward swing opening gates open
- a step stool permanently attached to the test stand (on catwalk) for the East gate

Cryostat Access Platform Details (Handrails, Gates, Step)




Is there any important reason that we should cut this out?

Do we want to add some piping caps for sharp edges?




West Catwalk Cleanup for Safe Traffic



The conduits 1,2 and 3 can't be removed until AC power distribution work as per Matt Micheli!


West Catwalk Cleanup for Safe Traffic (continued)



The Unistruts 4 and 5 can be arranged to be removed.


Delaying decision to remove until we decide how to extend the floor in order to support a MINERvA detector electronics maintenance.

West Catwalk Cleanup for Safe Traffic (continued)



Wireway 6 and 7 will stay. We need them as per Matt Micheli.

West Catwalk Cleanup for Safe Traffic (continued)



Water leak on the East Catwalk

