

## BNB: 9AM Meeting

- Sun May 28<sup>th</sup>: Turned off beam to BNB due to low RAW resistivity: elog[241688](#)
- Thu Jun 1<sup>st</sup>: Changed DI bottle for RAW system: elog[241838](#) & elog[241860](#)
  - Turned beam on the same day
  - Thanks to TSD, Safety, Ops, Booster, Linac