



400 MEV TEST AREA

SECTION III CHAPTER 02 OF THE FERMILAB SAD

Revision 3 November 20, 2023

This Chapter of the Fermilab Safety Assessment Document (SAD) contains a summary of the results of the Safety Analysis for the 400 MeV Test Area (MTA) segment of the Fermilab Main Accelerator that are pertinent to understanding the risks to the workers, the public, and the environment due to its operation.

SAD Chapter Review

This Section III, Chapter 02 of the Fermi National Accelerator Laboratory (Fermilab) Safety Assessment Document (SAD), *400 MeV Test Area*, was prepared and reviewed by the staff of the External Beam Delivery Department in conjunction with the Environment, Safety & Health Division (ESH) Accelerator Safety Department.

Signatures below indicate review of this Chapter, and recommendation that it be approved and incorporated into the Fermilab SAD.

Line Organization Owner

Accelerator Safety Department Head

SAD Review Subcommittee Chair

Revision History

Printed versions of this Chapter of the Fermilab Safety Assessment Document (SAD) may not be the currently approved revision. The current revision of this Chapter can be found on ESH DocDB #1066 along with all other current revisions of all Chapters of the Fermilab SAD.

Author	Rev. No.	Date	Description of Change
Herman B. White	0	January 20, 2011	Initial release of the MuCool Test Area Chapter for the Fermi National Accelerator Safety Assessment Document (SAD)
T. Kobilarcik E. Niner	1	August 25, 2020	Updated to align with new shielding assessment, infrastructure modifications, and repurposing as the MeV Test Area (MTA) for studies of the effects of radiation on components and materials.
S. McGimpsey	2	August 7, 2023	Updated for use with the new template and editorial changes.
S. McGimpsey C. Johnstone	3	November 20, 2023	Incorporation of the maximum credible incident for a radiological hazard and a description of the credited controls that mitigate it, along with any elements that are considered defense in depth.

Table of Contents

SAD Chapter Review	2
Revision History	4
Table of Contents	6
Acronyms and Abbreviations	10
III-2. 400 MeV Test Area.....	16
III-2.1. Introduction	16
III-2.1.1 Purpose/Function.....	16
III-2.1.2 Current Status	16
III-2.1.3 Description	16
III-2.1.4 Location.....	17
III-2.1.5 Management Organization	18
III-2.1.6 Operating Modes	18
III-2.1.7 Inventory of Hazards.....	19
III-2.2. Safety Assessment	20
III-2.2.1 Radiological Hazards	20
III-2.2.1.1 Prompt Ionizing Radiation.....	21
III-2.2.1.2 Residual Activation.....	21
III-2.2.1.3 Groundwater Activation	22
III-2.2.1.4 Surface Water Activation	22
III-2.2.1.5 Radioactive Water (RAW) Systems	22
III-2.2.1.6 Air Activation.....	22
III-2.2.1.7 Closed Loop Air Cooling	23
III-2.2.1.8 Soil Interactions	23
III-2.2.1.9 Radioactive Waste	23
III-2.2.1.10 Contamination	24
III-2.2.1.11 Beryllium-7.....	24
III-2.2.1.12 Radioactive Sources.....	24
III-2.2.1.13 Nuclear Material	24
III-2.2.1.14 Radiation Generating Devices (RGDs)	24
III-2.2.1.15 Non-Ionizing Radiation Hazards	24
III-2.2.2 Toxic Materials	25

- III-2.2.2.1 Lead 25
- III-2.2.2.2 Beryllium 25
- III-2.2.2.3 Fluorinert & Its Byproducts 25
- III-2.2.2.4 Liquid Scintillator Oil 25
- III-2.2.2.5 Pseudocumene 25
- III-2.2.2.6 Ammonia 25
- III-2.2.2.7 Nanoparticle Exposures 26
- III-2.2.3 Flammables and Combustible Materials 26
- III-2.2.4 Electrical Energy 26
 - III-2.2.4.1 Stored Energy Exposure 26
 - III-2.2.4.2 High Voltage Exposure 26
 - III-2.2.4.3 Low Voltage, High Current Exposure 26
- III-2.2.5 Thermal Energy 26
 - III-2.2.5.1 Bakeout 26
 - III-2.2.5.2 Hot Work 27
 - III-2.2.5.3 Cryogenics 27
- III-2.2.6 Kinetic Energy 27
 - III-2.2.6.1 Power Tools 27
 - III-2.2.6.2 Pumps and Motors 27
 - III-2.2.6.3 Motion Tables 27
 - III-2.2.6.4 Mobile Shielding 27
- III-2.2.7 Potential Energy 28
 - III-2.2.7.1 Crane Operations 28
 - III-2.2.7.2 Compressed Gasses 28
 - III-2.2.7.3 Vacuum/Pressure Vessels/Piping 28
 - III-2.2.7.4 Vacuum Pumps 28
 - III-2.2.7.5 Material Handling 28
- III-2.2.8 Magnetic Fields 28
 - III-2.2.8.1 Fringe Fields 29
- III-2.2.9 Other Hazards 29
 - III-2.2.9.1 Confined Spaces 29
 - III-2.2.9.2 Noise 29

- III-2.2.9.3 Silica 29
- III-2.2.9.4 Ergonomics..... 29
- III-2.2.9.5 Asbestos 29
- III-2.2.9.6 Working at Heights..... 30
- III-2.2.10 Access & Egress 30
 - III-2.2.10.1 Life Safety Egress 30
- III-2.2.11 Environmental..... 30
- III-2.3. Maximum Credible Incident (MCI) Scenario(s) for the Accelerator Specific Hazard(s) 30
 - III-2.3.1 Definition of the Maximum Credible Incident 30
 - III-2.3.1.1 Radiological Hazard..... 30
- III-2.4. Summary of Credited Controls..... 31
 - III-2.4.1 Credited Engineering Controls 31
 - III-2.4.1.1 Passive Credited Controls 31
 - III-2.4.1.1.1 Permanent Shielding Including Labyrinths 31
 - III-2.4.1.1.2 Penetration and movable Shielding 33
 - III-2.4.2 Active Engineered Credited Controls 33
 - III-2.4.2.1 Radiation Safety Interlock System 34
 - III-2.4.2.2 ODH Safety System 35
 - III-2.4.3 Administrative Credited Controls 35
 - III-2.4.3.1 Enclosure Search and Secure Process 35
 - III-2.4.3.2 Operation Authorization Document 36
 - III-2.4.3.3 Staffing 36
- III-2.5. Defense-in-Depth Controls 36
 - III-2.5.1 Fencing and Posting 36
 - III-2.5.2 Training 36
 - III-2.5.3 Procedures 36
- III-2.6. Machine Protection Controls 37
- III-2.7. Decommissioning..... 37
- III-2.8. Summary and Conclusion..... 37
- III-2.9. References 37
- III-2.10. Appendix – Risk Matrices 38

Acronyms and Abbreviations

ACGIH	American Conference of Governmental Industrial Hygienists
ACNET	Accelerator Control Network System
AD	Accelerator Directorate
AHJ	Authority Having Jurisdiction
ALARA	As Low As Reasonably Achievable
ANSI	American National Standards Institute
APS-TD	Applied Physics and Superconducting Technology Directorate
ARA	Airborne Radioactivity Area
ASE	Accelerator Safety Envelope
ASHRAE	American Society of Heating, Refrigerating and Air Conditioning Engineers
ASME	American Society of Mechanical Engineers
ASO	Accelerator Safety Order, referring to DOE O 420.2D <i>Safety of Accelerators</i>
⁷ Be	Beryllium-7
BLM	Beam Loss Monitor
BNB	Booster Neutrino Beam
BPM	Beam Position Monitor
BY	Boneyard
CA	Controlled Area
CA	Contamination Area
CAS	Contractor Assurance System
CC	Credited Control
CCL	Coupled Cavity Linac
CDC	Critical Device Controller
CERN	European Organization for Nuclear Research
CFM	Cubic Feet per Minute
CFR	Code of Federal Regulations (United States)
Ci	Curie
CLW	Co-Located Worker (the worker in the vicinity of the work but not actively participating)
cm	centimeter
CPB	Cryogenics Plant Building
CSO	Chief Safety Officer
CUB	Central Utility Building
CW	Continuous Wave
CX	Categorically Excluded
D&D	Decontamination and Decommissioning
DA	Diagnostic Absorber
DAE	Department of Atomic Energy India

DCS	Derived Concentration Standard
DocDB	Document Database
DOE	Department of Energy
DOT	Department of Transportation
DR	Delivery Ring
DSO	Division Safety Officer
DSS	Division Safety Specialist
DTL	Drift Tube Linac
DUNE	Deep Underground Neutrino Experiment
EA	Environmental Assessment
EA	Exclusion Area
EAV	Exhaust Air Vent
EENF	Environmental Evaluation Notification Form
EMS	Environmental Management System
EOC	Emergency Operations Center
EPA	Environmental Protection Agency
ES&H	Environment, Safety and Health
Fermilab	Fermi National Accelerator Laboratory, see also FNAL
FESHCom	Fermilab ES&H Committee
FESHM	Fermilab Environment, Safety and Health Manual
FHS	Fire Hazard Subcommittee
FIRUS	Fire Incident Reporting Utility System
FNAL	Fermi National Accelerator Laboratory, see also Fermilab
FODO	Focus-Defocus
FONSI	Finding of No Significant Impact
FQAM	Fermilab Quality Assurance Manual
FRA	Fermi Research Alliance
FRCM	Fermilab Radiological Control Manual
FSO	Fermilab Site Office
FW	Facility Worker (the worker actively performing the work)
GERT	General Employee Radiation Training
GeV	Giga-electron Volt
³ H	Tritium
HA	Hazard Analysis
HAR	Hazard Analysis Report
HCA	High Contamination Area
HCTT	Hazard Control Technology Team
HEP	High Energy Physics
HFD	Hold for Decay

HLCF	High Level Calibration Facility
HPR	Highly Protected Risk
Hr	Hour
HRA	High Radiation Area
HSSD	High Sensitivity Air Sampling Detection
HVAC	Heating, Ventilation, and Air Conditioning
HWSF	Hazardous Waste Storage Facility
Hz	Hertz
IB	Industrial Building
IBC	International Building Code
ICW	Industrial Cooling Water
IEPA	Illinois Environmental Protection Agency
IEEE	Institute of Electrical and Electronics Engineers
INFN	Istituto Nazionale di Fisica Nucleare
IMPACT	Integrated Management Planning and Control Tool
IPCB	Illinois Pollution Control Board
IQA	Integrated Quality Assurance
ISD	Infrastructure Services Division
ISM	Integrated Safety Management
ITNA	Individual Training Needs Assessment
KeV	kilo-electron volt
kg	kilo-grams
kW	kilo-watt
LBNF	Long Baseline Neutrino Facility
LCW	Low Conductivity Water
LHC	Large Hadron Collider
LLCF	Low Level Calibration Facility
LLWCP	Low Level Waste Certification Program
LLWHF	Low Level Waste Handling Facility
LOTO	Lockout/Tagout
LPM	Laser Profile Monitor
LSND	Liquid Scintillator Neutrino Detector
LSO	Laser Safety Officer
m	meter
mA	milli-amp
MABAS	Mutual Aid Box Alarm System
MARS	Monte Carlo Shielding Computer Code
MC	Meson Center
MC&A	Materials Control and Accountability

MCI	Maximum Credible Incident
MCR	Main Control Room
MEBT	Medium Energy Beam Transport
MEI	Maximally Exposed Individual
MeV	Mega-electron volt
MI	Main Injector
MINOS	Main Injector Neutrino Oscillation Search
MMR	Material Move Request
MOI	Maximally-Exposed Offsite Individual (<i>Note: due to the Fermilab Batavia Site being open to the public, the location of the MOI is taken to be the location closest to the accelerator that is accessible to members of the public.</i>)
MP	Meson Polarized
mrad	milli-radian
mrem	milli-rem
mrem/hr	milli-rem per hour
MT	Meson Test
MTA	400 MeV Test Area
MTF	Magnet Test Facility
²² Na	Sodium-22
NC	Neutrino Center
NE	Neutrino East
NEC	National Electrical Code
NEPA	National Environmental Policy Act
NESHAPS	National Emissions Standards for Hazardous Air Pollutants
NFPA	National Fire Protection Association
NM	Neutrino Muon
NMR	Nuclear Material Representative
NOvA	Neutrino Off-axis Electron Neutrino (ν_e) Appearance
NPH	Natural Phenomena Hazard
NRTL	Nationally Recognized Testing Laboratory
NIF	Neutron Irradiation Facility
NTSB	Neutrino Target Service Building, see also TSB
NuMI	Neutrinos at the Main Injector
NW	Neutrino West
ODH	Oxygen Deficiency Hazard
ORC	Operational Readiness Clearance
OSHA	Occupational Safety and Health Administration
pCi	pico-Curie
pCi/mL	pico-Curie per milliliter

PE	Professional Engineer
PIN	Personal Identification Number
PIP	Proton Improvement Plan
PIP-II	Proton Improvement Plan - II
PHAR	Preliminary Hazards Analysis Report
PPD	Particle Physics Directorate
PPE	Personnel Protective Equipment
QA	Quality Assurance
QAM	Quality Assurance Manual
RA	Radiation Area
RAF	Radionuclide Analysis Facility
RAW	Radioactive Water
RCT	Radiological Control Technician
RF	Radio-Frequency
RFQ	Radio-Frequency Quadrupole
RIL	RFQ Injector Line
RMA	Radioactive Material Area
RMS	Root Mean Square
RPCF	Radiation Physics Calibration Facility
RPE	Radiation Physics Engineering Department
RPO	Radiation Physics Operations Department
RRM	Repetition Rate Monitor
RSI	Reviewed Safety Issue
RSIS	Radiation Safety Interlock System
RSO	Radiation Safety Officer
RWP	Radiological Work Permit
SA	Shielding Assessment
SAA	Satellite Accumulation Areas
SAD	Safety Assessment Document
SCF	Standard Cubic Feet
SCFH	Standard Cubic Feet per Hour
SEWS	Site-Wide Emergency Warning System
SNS	Spallation Neutron Source
SR	Survey Riser
SRF	Superconducting Radio-Frequency
SRSO	Senior Radiation Safety Officer
SSB	Switchyard Service Building
SSP	Site Security Plan
SWIC	Segmented Wire Ionization Chambers

TLM	Total Loss Monitor
TLVs	Threshold Limit Values
TPC	Time Projection Chamber
TPES	Target Pile Evaporator Stack
TPL	Tagged Photon Lab
TSB	Target Service Building, see also NTSB
TSCA	Toxic Substances Control Act
TSW	Technical Scope of Work
T&I	Test and Instrumentation
UPB	Utility Plant Building
UPS	Uninterruptible Power Supply
USI	Unreviewed Safety Issue
VCTF	Vertical Cavity Test Facility
VHRA	Very High Radiation Area
VMS	Village Machine Shop
VMTF	Vertical Magnet Test Facility
VTS	Vertical Test Stand
WSHP	Worker Safety and Health Program
μs	micro-second

III-2. 400 MeV Test Area

III-2.1. Introduction

This Section III, Chapter 02 of the Fermi National Accelerator Laboratory (Fermilab) Safety Assessment Document (SAD) covers the 400 MeV Test Area (MTA) segment of the Fermilab Main Accelerator.

III-2.1.1 [Purpose/Function](#)

The purpose of the 400 MeV Test Area is to provide 400 MeV H⁻ or protons to the MTA. The 400 MeV Test Area was originally designed to test the feasibility of ionization cooling of the high-power ionizing beam from the Fermilab Linac, passing through a liquid hydrogen energy absorber. The beam line, and associated experimental hall, have been repurposed for studying the effects of radiation on various components and materials.

III-2.1.2 [Current Status](#)

The MTA segment of the Fermilab Main Accelerator is currently: **operational**.

III-2.1.3 [Description](#)

The MTA enclosure is located southwest of the Linac accelerator. See Figure 1. The MTA beam line begins with two C magnets that extract beam from the downstream portion of the Linac. A four-dipole bend string then directs beam through a shield wall, separating the Linac tunnel and the MTA enclosure, and then into the MTA enclosure.

In the MTA enclosure, beam emerges at the end of the beam line through a titanium vacuum window and continues through air, passing down the center of a shielding cave constructed of concrete shielding blocks. The cave offers a passage three feet across and three feet high, with at least three feet of shielding block material all around. Target material can be irradiated at the center of this volume. The shielding cave floor extends an additional three feet toward the vacuum window, making a “front porch” area which serves as another position for target material. Beam that does not interact with target materials is absorbed in the final beam absorber located beyond the downstream wall of the experimental hall.

Several multiwire beam profile monitors, beam loss monitors, and diagnostic beam toroids are installed along the beamline to assess the beam’s trajectory. A full intensity beam absorber is located at the downstream end of the facility.

The experimental area will be used by experimenters to study the effects of radiation on components and materials placed in the MTA beamline. These experiments may make use of motion tables, cooling units, power supplies, and fluence monitoring to control and monitor samples under test. The character of the hazards associated with these planned experiments is similar but may vary in magnitude. New experiments are screened for hazards through the Operational Readiness Clearance (ORC) process coordinated by the ORC chairperson for the respective area prior to approval. Such experiments would be similar in ES&H impact to those described here.




Figure 1. MTA Experimental Hall

III-2.1.4 Location

The MTA segment of the Fermilab Main Accelerator is located on the Fermilab site in Batavia, IL.



Figure 2. Regional view showing the location of the Fermilab site in Batavia, IL.

The MTA is located in the central campus on the Fermilab site. Members of the public are not invited to the MTA.



Figure 3. Aerial view of the Fermilab site, indicating the location of the MTA.

III-2.1.5 Management Organization

The MTA facility is owned and operated by the Accelerator Directorate. The Irradiation Test Area (ITA), managed by the Particle Physics Division, conducts experiments within the MTA experimental hall.

III-2.1.6 Operating Modes

The “Shielding Assessment Document for the MeV Test Area at the Fermilab Linac End station”[2] (the shielding assessment) demonstrates that the MTA is capable of receiving 400 MeV ions from the end of the Linac at an intensity of $2.7E15$ protons per hour average flux. The MTA supports two modes of operation: H⁻ and protons.

In proton mode, the stripping foil is inserted in the beamline upstream of the final bend. The stripping foil removes electrons from the H⁻ ion. The final bend then directs protons to the test apparatus. Stripped electrons and neutral hydrogen are absorbed above the beamline. Protons which do not interact with the test apparatus continue to the final absorber.

In H⁻ mode, the stripping foil is retracted from the beamline, and the final bend directs H⁻ to the test apparatus. Particles which do not interact with the test apparatus continue to the final absorber.

The MTA can deliver 1 or 8 pulses per minute at 15 Hz, with a variable pulse length of 7us to 32us.

III-2.1.7 Inventory of Hazards

The following table lists all the identified hazards found in the MTA enclosure and support buildings. Section III-2.10 *Appendix – Risk Matrices* describes the baseline risk (i.e., unmitigated risk), any preventative controls and/or mitigative controls in place to reduce the risk, and residual risk (i.e., mitigated risk) for facility worker, co-located worker and Maximally Exposed Offsite Individual (MOI) (i.e., members of the public). A summary of these controls is described within Section III-2.2 *Safety Assessment*.

Prompt ionizing and Oxygen Deficiency Hazards due to cryogenic systems within accelerator enclosures have been identified as accelerator specific hazards, and as such their controls are identified as Credited Controls. The analysis of these hazards and their Credited Controls will be discussed within this SAD Chapter, and their Credited Controls summarized in the Accelerator Safety Envelope for the Fermilab Main Accelerator. Accelerator specific controls are identified as **purple/bold** throughout this Chapter.

All other hazards present in the MTA are safely managed by other DOE approved applicable safety and health programs and/or processes, and their analyses have been performed according to applicable DOE requirements as flowed down through the Fermilab Environment, Safety and Health Manual (FESHM). These hazards are Standard Industrial Hazards (SIH), and their analysis will be summarized in this SAD Chapter.

Table 1. Hazard Inventory for MTA.

Radiological		Toxic Materials	
<input checked="" type="checkbox"/>	Prompt Ionizing Radiation	<input checked="" type="checkbox"/>	Lead
<input checked="" type="checkbox"/>	Residual Activation	<input checked="" type="checkbox"/>	Beryllium
<input checked="" type="checkbox"/>	Groundwater Activation	<input type="checkbox"/>	Fluorinert & Its Byproducts
<input checked="" type="checkbox"/>	Surface Water Activation	<input checked="" type="checkbox"/>	Liquid Scintillator Oil
<input type="checkbox"/>	Radioactive Water (RAW) Systems	<input type="checkbox"/>	Ammonia
<input checked="" type="checkbox"/>	Air Activation	<input type="checkbox"/>	Nanoparticle Exposures
<input type="checkbox"/>	Closed Loop Air Cooling	Flammables and Combustibles	
<input checked="" type="checkbox"/>	Soil Interactions	<input checked="" type="checkbox"/>	Combustible Materials (e.g., cables, wood cribbing, etc.)
<input checked="" type="checkbox"/>	Radioactive Waste	<input checked="" type="checkbox"/>	Flammable Materials (e.g., flammable gas, cleaning materials, etc.)
<input checked="" type="checkbox"/>	Contamination	Electrical Energy	
<input checked="" type="checkbox"/>	Beryllium-7	<input checked="" type="checkbox"/>	Stored Energy Exposure
<input checked="" type="checkbox"/>	Radioactive Sources	<input checked="" type="checkbox"/>	High Voltage Exposure
<input type="checkbox"/>	Nuclear Material	<input checked="" type="checkbox"/>	Low Voltage, High Current Exposure
<input type="checkbox"/>	Radiation Generating Devices (RGDs)	Kinetic Energy	
<input checked="" type="checkbox"/>	Non-Ionizing Radiation Hazards	<input checked="" type="checkbox"/>	Power Tools
Thermal Energy		<input checked="" type="checkbox"/>	Pumps and Motors
X	Bakeout	<input checked="" type="checkbox"/>	Motion Tables
X	Hot Work	<input checked="" type="checkbox"/>	Mobile Shielding
<input checked="" type="checkbox"/>	Cryogenics	Magnetic Fields	
Potential Energy		<input checked="" type="checkbox"/>	Fringe Fields
<input type="checkbox"/>	Crane Operations	Other Hazards	
<input checked="" type="checkbox"/>	Compressed Gasses	<input type="checkbox"/>	Confined Spaces
<input checked="" type="checkbox"/>	Vacuum/Pressure Vessels/Piping/Pipe	<input checked="" type="checkbox"/>	Noise
<input checked="" type="checkbox"/>	Vacuum Pumps	<input checked="" type="checkbox"/>	Silica
<input checked="" type="checkbox"/>	Material Handling	<input checked="" type="checkbox"/>	Ergonomics
Access & Egress		<input checked="" type="checkbox"/>	Asbestos
<input checked="" type="checkbox"/>	Life Safety Egress	<input checked="" type="checkbox"/>	Working at Heights

III-2.2. Safety Assessment

All hazards for the MTA segment of the Fermilab Main Accelerator are summarized in this section, with additional details of the analyses for accelerator specific hazards.

III-2.2.1 Radiological Hazards

The MTA presents radiological hazards in the form of Prompt Ionizing Radiation, Residual Activation, Groundwater Activation, Surface Water Activation, Radioactive Air Activation, Soil Interactions, Radioactive Waste, Contamination, Beryllium-7, and Radioactive Sources. A detailed shielding assessment [2] addresses these hazards and provide a detailed analysis of the facility demonstrating the required shielding, controls and interlocks to comply with the Fermilab Radiological Control Manual (FRCM) [1]. Radiation safety has been carefully considered in the design of the MTA. There are two predominant radiation hazards. The first hazard is due to the interaction of beam particles in the materials surrounding the beam pipes, beam line elements, and test equipment. The second is caused by the interaction of beam

particles in the test components and the subsequent interactions of the secondaries with their surrounding material.

There are three categories of beam-induced radiation hazards:

1. Prompt radiation levels inside and surrounding the enclosure that are present during beam transport. These include protons, neutrons, muons, and other energetic particles.
2. Residual radiation due to activation of beamline components, and experimental devices which can give rise to radiation exposure to personnel during accesses to the beam enclosure and experimental facility for repair, maintenance, inspection, and operation activities; and
3. Environmental radioactivity due to the operation of the beam transport system, such as the activation of air, soil, and groundwater.

A detailed shielding assessment [2] has been compiled and reviewed to address these concerns. The assessment provides a detailed analysis of this facility, demonstrating the required overburden, use of signs, fences, and active interlocks to comply with the Fermilab Radiological Control Manual (FRCM)[1]. Residual activation of components makes a substantial impact on the ability to occupy the experimental hall where recurring access is required for routine experimental equipment changes. The shielding assessment has analyzed the beam line areas from the Linac extraction through the MTA experimental enclosure.

III-2.2.1.1 Prompt Ionizing Radiation

When beam is transported through the MTA Beamline, prompt ionizing radiation is a significant radiation hazard. In order to protect workers and the general public, the enclosure and beam pipes are surrounded by sufficient amounts of shielding or networks of interlocked detectors. Prompt radiation is kept within acceptable levels. Operation of the area conforms to the FRCM and to maintain exposures for operating personnel as-low-as-reasonably-achievable (ALARA).

With the use of signs, fences, gates, locks, interlocked radiation detectors, and the radiation safety interlock system, there is sufficient shielding to protect individuals from beam-on radiation hazards in and around the MTA Beamline and facility. Results of risk assessment, Risk Tables 2.1 through 2.3, have been demonstrated that baseline risk has reduced from a value of I to a residual risk of III or IV when preventive and mitigative measures are considered.

III-2.2.1.2 Residual Activation

High intensity beam delivery in the MTA will produce activated materials inside the enclosure. Exposure is kept ALARA by a combination of shielding (provided by the shielding cave) and cool off time.

The residual dose at the exterior surface of the shielding cave has been calculated for 12 hours of operating at $5E12$ protons per second (average). The residual dose is less than 30 mrem/hr after one hour of cool-off, and less than 5 mrem/hr after one day of cool-off. (Note: $5E12$ protons per second was chosen for ease of scaling and is in excess of the expected $2.7E15$ protons per hour, or $7.5E11$ protons per second, average flux).

Access to activated components in the experimental area is tightly controlled. All potential residual activation hazards are handled operationally as in all other primary beam enclosures. These controls include verification of training, centralized authorization, and key entry. The level of control depends on the level of residual radiation. In addition, no access into the MTA enclosure is permitted until the air monitor (G: RD0236) is reading less than 400 cpm. The controls will follow the administrative controls and safety guidelines found in the radiological work permit (RWP) and running condition. In most cases, the typical RWP for accesses will suffice. A job specific RWP and an ALARA plan will be required for work on any highly activated equipment or work within the posted Contamination Area. Results of risk assessment have been demonstrated that baseline risk has reduced from a value of I to a residual risk of IV when preventive and mitigative measures are considered.

III-2.2.1.3 Groundwater Activation

Radioactivity induced by the interaction of high-energy particles with the soil that surrounds a proton target is addressed in this section. The production of tritium and sodium-22 poses the greatest concern, since the product of the production rate, leachability into the water flowing through the soil, and decay half-lives of these nuclides may be large. Fermilab standards pertaining to groundwater activation are provided in FRCM Chapters 3 and 11[1], and methodologies for estimating groundwater activation are given in Environmental Protection Notes Numbers 8 and 17. The methodology is designed to achieve a conservative estimate of groundwater activation. Additionally, the annual integrated intensity used in the calculations is estimated well above the practical beam delivery limits.

As discussed in the shielding assessment [2], the simulation program MARS[4] has been used to estimate the surface water and groundwater activation concentrations in the vicinity of the final beam absorber. The shielding assessment demonstrates that the operation of beam to the absorber will be well within any limits set by surface or ground water activity.

Additional calculations were performed to determine the annual integrated intensity limits for the facility for surface and ground water activation. The shielding assessment determined that $1.3E18$ protons per year could be sent to the final beam absorber without exceeding the FRCM ground water limits. Since Fermilab has mandatory shutdown every Summer, typically lasting 12-15 weeks, MTA is not operational for a full calendar year. MTA is typically operational for about 40 weeks/year. Results of risk assessment, Tables 2.1 through 2.3, have been demonstrated that baseline risk has been reduced from a value of I to a residual risk of III or IV when preventive and mitigative measures are considered.

III-2.2.1.4 Surface Water Activation

See ground water activation section above

III-2.2.1.5 Radioactive Water (RAW) Systems

N/A.

III-2.2.1.6 Air Activation

Illinois state regulations and the Fermilab registration in Registration of Smaller Sources (ROSS) program, administered by the Illinois Environmental Protection Agency (IEPA), govern releases of airborne radionuclides. The regulations limit the effective dose equivalent delivered to a member of the public to 10 mrem/year [1]. Fermilab has established a secondary goal of keeping the maximum effective dose equivalent at the site boundary due to air emissions under 0.1 mrem/yr.

The principal radionuclides of concern to air activation are carbon-11 (which has a 20-minute half-life), nitrogen-13 (which has about a 10-minute half-life), oxygen-15 (which has about a 2-minute half-life), tritium (which has 4500 day half-life), and argon-41 (with a 110 minute half-life, which is produced by thermal neutron capture on argon-40). Normally the ventilation systems in the enclosure would have a slow air transit time in minutes through protected areas before air is released to an outdoor area, which helps eliminate the short-lived particle emitters through decay during the transit time.

Air activation for MTA is considered in the shielding assessment [2]. For an assumed intensity of $1.3E18$ protons per year, and a natural air exchange rate of 200 cfm, which is an overestimate, the anticipated release to the atmosphere is 0.99 Ci/year. Based on releases expected from the existing accelerators and the current and near future experiments, Fermilab will remain in compliance with EPA requirements [3]. Results of risk assessment have been demonstrated that baseline risk has reduced from a value of I to a residual risk of IV when preventive and mitigative measures are considered.

III-2.2.1.7 Closed Loop Air Cooling

N/A.

III-2.2.1.8 Soil Interactions

The hazards due to worker, co-located worker or public interaction due to interactions with soil have been evaluated by a qualitative assessment. The baseline qualitative risk was determined to be a risk level of IV (minimal concern). The consequences from potential exposure to this hazard is considered to be of negligible consequence, and since this material is inaccessible to workers, co-located workers and public due to where it may found within the facility, no preventive or mitigative measures are required, the risk is of a minimal concern, and not subject to additional evaluation.

III-2.2.1.9 Radioactive Waste

Radioactive waste produced in the course of MTA operations will be managed within the established Radiological Protection Program (RPP) and as prescribed in the Fermilab Radiological Control Manual (FRCM). This includes incidental radioactive materials produced during the irradiation of target materials, as well as beamline components that that have been hit by the beam.

Radioactive waste is a standard radiological hazard that is managed within the established Radiological Protection Program (RPP) and as prescribed in the Fermilab Radiological Control Manual (FRCM). Waste minimization is an objective of the equipment design and operational procedures. Although production of radioactive material is not an operational function of the MTA, beam loss and, in the case of some beam diagnostics devices, intentional interception of the beam will result in activation of beam line elements. Reuse of activated items will be carried out when feasible. Activated items that cannot be reused will be

disposed of as radioactive waste in accordance with the FRCM requirements. Results of risk assessment have been demonstrated that baseline risk has reduced from a value of I to a residual risk of IV when preventive and mitigative measures are considered.

III-2.2.1.10 Contamination

Although not typically encountered throughout the MTA enclosure, a well-defined and roped off posted contamination area is present around the front porch where the experimental set ups are located. Personnel are required by the RWP to appropriate PPE (double shoe cover and gloves when in controlled access) when accessing this area, and an RCT must be continually present. The hazards due to worker, co-located worker or public interaction due to contamination have been evaluated by a qualitative assessment. The baseline qualitative risk was determined to be a risk level of IV (minimal concern). The consequences from potential exposure to this hazard is considered to be of negligible consequence, and since this material is inaccessible to workers, co-located workers and public due to where it may found within the facility, no preventive or mitigative measures are required, the risk is of a minimal concern, and not subject to additional evaluation.

III-2.2.1.11 Beryllium-7

As mentioned above, the posted contamination area is present around the front porch of the experimental area. Beryllium-7 is a predominant radioisotope present in this area. The hazards due to worker, co-located worker or public interaction with Beryllium-7 and other contamination have been evaluated by a qualitative assessment. The baseline qualitative risk was determined to be a risk level of IV (minimal concern). The consequences from potential exposure to this material is considered to be of negligible consequence, and since this material is inaccessible to workers, co-located workers and public due to where it may found within the facility, coupled with the very short half-lives, no preventive or mitigative measures are required, the risk is of a minimal concern, and not subject to additional evaluation.

III-2.2.1.12 Radioactive Sources

The hazards due to worker, co-located worker or public interaction due to radioactive source use have been evaluated by a qualitative assessment. The baseline qualitative risk was determined to be a risk level of IV (minimal concern). The consequences from potential exposure to this hazard is considered to be of negligible consequence, and since this material is inaccessible to workers, co-located workers and public due to where it may found within the facility, no preventive or mitigative measures are required, the risk is of a minimal concern, and not subject to additional evaluation.

III-2.2.1.13 Nuclear Material

N/A.

III-2.2.1.14 Radiation Generating Devices (RGDs)

N/A.

III-2.2.1.15 Non-Ionizing Radiation Hazards

It is anticipated that lasers may need to be brought into the MTA enclosure, for experimental purposes. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04 *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.2 Toxic Materials

The MTA presents toxic material hazards identified in Table 2. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.2.1 Lead

The primary lead hazard is in the form of lead solder from older electronics that are still in use. Lead radiation shielding is used in MTA counting house, typically in the form of encased lead blankets. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.2.2 Beryllium

While not expected, this SAD considers that Beryllium may need to be brought into the MTA enclosure, for experimental purposes. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.2.3 Fluorinert & Its Byproducts

N/A.

III-2.2.2.4 Liquid Scintillator Oil

It is anticipated that liquid scintillator oil may need to be brought into the MTA enclosure, for experimental purposes. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.2.5 Pseudocumene

It is anticipated that pseudocumene may need to be brought into the MTA enclosure, for experimental purposes. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.2.6 Ammonia

N/A.

III-2.2.2.7 Nanoparticle Exposures

N/A.

III-2.2.3 [Flammables and Combustible Materials](#)

Common industrial lubricants, solvents, and paints are used by technicians to maintain equipment and are stored in flammable materials lockers. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.4 [Electrical Energy](#)

Electrical hazards are present in the form of low and high voltage power supplies that power magnets, ion pumps and diagnostic equipment. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.4.1 [Stored Energy Exposure](#)

The MTA electrical hazards from the alternating current (AC) power distribution systems and the power supplies mentioned in the previous section have been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.4.2 [High Voltage Exposure.](#)

See previous sections III-2.2.4 and III-2.2.4.1. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.4.3 [Low Voltage, High Current Exposure](#)

See previous sections III-2.2.4 and III-2.2.4.1. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.5 [Thermal Energy](#)

This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.5.1 [Bakeout](#)

Historically, MTA does not do magnet or beam pipe bakeouts. However, if there is a need to do bakeouts, this hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04

Safety Analysis. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.5.2 Hot Work

Qualified welders could occasionally need to work in the enclosure to repair waterlines and other metalwork. Hot work in MTA areas has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04 *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.5.3 Cryogenics

It is anticipated that experiments may require cryogenic liquids. This hazard is addressed in the oxygen deficiency hazard section and has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.6 Kinetic Energy

This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.6.1 Power Tools

Power tools are commonly used when working on MTA equipment in the enclosure, counting house and linac gallery. Power tool use has This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.6.2 Pumps and Motors

Standard industrial pumps and motors are utilized in the MTA area for water cooling and vacuum systems. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.6.3 Motion Tables

MTA experiments use a mechanical motion table to position target materials at selected locations or for optimal beam irradiation. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.6.4 Mobile Shielding

This hazard is addressed in the shielding sections below and have been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.7 [Potential Energy](#)

This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.7.1 [Crane Operations](#)

N/A.

III-2.2.7.2 [Compressed Gasses](#)

It is anticipated that compressed gasses may need to be brought into the MTA enclosure, for experimental purposes. ArCO₂ is used in beam line diagnostic components. These gas cylinders are securely stored in the MTA gas shed. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.7.3 [Vacuum/Pressure Vessels/Piping](#)

Vacuum vessels are present in Linac in the form of beam pipes or other beamline components. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.7.4 [Vacuum Pumps](#)

Vacuum pumps are used throughout the MTA beam line to maintain vacuum in the beamline and other components. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.7.5 [Material Handling](#)

Trained personnel operate a forklift or hand carts to move materials throughout the MTA area. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.8 [Magnetic Fields](#)

This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.8.1 Fringe Fields

The fringe field hazard mainly comes from electromagnets, permanent magnets and permanent magnets that are in ion pumps. Fields are nominally only hazardous to people who have medical device implants. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.9 [Other Hazards](#)

III-2.2.9.1 Confined Spaces

This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.9.2 Noise

Operational beamline systems or experimental set-ups, have the potential to create a noise hazard. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.9.3 Silica

Silica dust may be created when drilling into concrete floors or walls. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.9.4 Ergonomics

Both office and technical work in MTA areas may involve sitting or standing for long periods of time, repetitive motion, cramped conditions, and other ergonomic concerns. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.9.5 Asbestos

Access penetrations connecting the Linac gallery to the MTA enclosure may be asbestos lined due to common fire prevention practices during the period when the building was constructed. Due to the age of the building, asbestos may be present in other areas as well. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.9.6 Working at Heights

Technicians utilize ladders, step stools, and mobile work platforms to conduct maintenance in the MTA areas. Utilizing fall protection equipment, trained personnel may work on top of equipment where there is a chance of falling. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.10 [Access & Egress](#)

III-2.2.10.1 Life Safety Egress

The MTA enclosure has access and egress points at both the upper level and the lower pit level. This hazard has been evaluated within the common Risk Matrix table included in SAD Section I Chapter 04, *Safety Analysis*. Work in MTA involving this hazard implements the controls specified in the common Risk Matrix table. No unique controls are in use.

III-2.2.11 [Environmental](#)

The MTA presents environmental hazards in the form of a list of checked off hazards shown in Table 2. All environmental hazards present in the MTA areas are in the form of Standard Industrial Hazards discussed in SAD Section I, Chapter 04.

III-2.3. Maximum Credible Incident (MCI) Scenario(s) for the Accelerator Specific Hazard(s)

III-2.3.1 [Definition of the Maximum Credible Incident](#)

This section of the MTA SAD evaluates the maximum credible incident (MCI) scenario that could happen in the MTA. Consideration and analysis of this MCI is focused on an onsite facility worker, onsite co-located worker, and a maximally exposed off-site individual (MOI).

III-2.3.1.1 Radiological Hazard

The MTA can provide protons or H⁻ ions from the Linac to the Irradiation Test Area (ITA) or to the final absorber for beam tuning. A maximum credible incident would be one that produces the greatest beam loss for the longest period of time. The MTA MCI is dependent on the intensity of the Linac resulting from the MCI for Linac. After careful evaluation, it has been determined that the Linac MCI, with respect to beam intensity, has the following beam parameters. At 400 MeV, Linac can achieve a maximum beam pulse length of 60 microseconds and beam current of 130 mA at 15 Hz. The maximum current is limited by the RFQ transmission, and the beam pulse width is limited by the SCL coupling cavities. See the Linac SAD chapter on maximum credible incident scenario(s) for the accelerator specific hazard(s) for more information.

As a result, the maximum beam intensity output that can be achieved from the Linac is 2.58E18 protons/hour, with 4.78E13 protons/pulse at 15 Hz. Since the two pulsed C magnets that extract beam horizontally into the MTA line can operate at the full 15 Hz cycle, the MCI for MTA will also need to take into account this maximum beam output of 2.58E18 protons/hr. A maximum credible incident would be

one that produces the greatest beam loss for the longest period of time. The MTA MCI occurs when 2.58×10^{18} protons/hour is lost and continuously incident on a beamline component that is both the closest to the thinnest section of permanent shielding and the farthest away from interlocked radiation detectors in the MTA beamline for one hour. This MCI in MTA can be a result of the misdirection of the beam so that it impacts the beam pipe and surrounding structures inside the accelerator enclosure, which can occur from a single failure of one or more devices or power supplies, or erroneous operation of them. Also, the C magnet's power supply is assumed to be left on and pulsing at 15 Hz for a full hour.

Prompt radiation causes hazardous radiation fields directly and indirectly through material effects. Assuming no shielding is present, this incident would result in a dose that far exceeds acceptable levels for radiation exposure to workers or members of the public. The MCI analysis finds that a peak dose rate of 9505 mrem/hr would occur at the surface of the MTA berm in this accident condition. Without any preventative or mitigative measures, the prompt radiation risk would be in the 'Likelihood: Anticipated; Consequence: High' risk category (category I).

Fermilab uses Credited Controls that flow down to the ASE to mitigate an MCI to less than 5R for workers and less than 500 mrem for non-public areas of the campus and less than 100 mrem for areas of the campus where the public is invited. This is below the negligible consequence level for radiation exposure to workers or members of the public as identified in DOE Handbook 1163, Consequence Matrix Figure C-1 for a radiological hazard. MTA is an area where members of the public are not invited.

III-2.4. Summary of Credited Controls

This section describes the credited controls that are required to reduce the risk associated with the MCI to a negligible consequence level.

III-2.4.1 Credited Engineering Controls

The purpose of this section is to provide the information necessary to understand the engineered controls, which can be active or passive, and administrative controls that are used to prevent or mitigate the consequences of the MCI. This analysis then verifies that the risk associated with the MTA MCI is reduced to a negligible level.

III-2.4.1.1 Passive Credited Controls

Passive controls are elements that are part of the physical design of the facility that require no action to function properly. These are fixed elements of the beamline that take direct human intervention to remove. The MTA enclosure is designed and constructed as a permanent concrete and earth-covered radiation shield that uses a combination of permanent shielding, movable shielding, and penetration shielding, to protect personnel from radiological exposure due to an MCI.

III-2.4.1.1.1 Permanent Shielding Including Labyrinths

The permanent shielding encompasses the structural elements surrounding the beamline components and experimental hall. The concrete structure is contiguous with the Linac and includes an upstream equipment access hatch, an equipment access pit on the south side of the experimental hall, a personnel access labyrinth with two exits, utility penetrations, and earthen berms and overburden.

There are two categories of beam-material interactions that are considered for the MTA shielding requirements for the MCI. The first is beam hitting a magnet in an enclosure, and the second is beam hitting the beam pipe in the enclosure. The MCI, is $2.58E18$ protons/hour hitting a magnet. This scenario requires 17.2 effective feet of dirt (e.f.d) to limit the radiation dose rate to less than 500 mrem-per-hour for a person outside of the beamline areas. See Table 1. If there is 17.2 e.f.d. of shielding that surrounds the MTA line, then a person outside of the beamline areas and right next to the shielding will receive at most a dose of 500 mrem within one hour from the assumed one hour of maximum beam power operations. Where sufficient shielding is present, the 17.2 e.f.d. is a credited control. There are a number of areas along the MTA beamline with less than 17.2 e.f.d. which will require active controls as described below in addition to the existing shielding. See Tables 2 and 3 for the shielding present along the MTA beamline berm.

Table 1. Scaled Shielding Requirements from the MTA shielding assessment

Effective Dose, D, per hour	A. Beam on Magnet in Enclosure	Primary Scaled (efd)	Secondary Scaled (efd)
	Category		
D < 1 mrem	1A	26.4	26.4
1 ≤ D < 5 mrem	2A	24.0	24.0
1 ≤ D ≤ 10 mrem	1SE-A	23.0	23.0
1 ≤ D ≤ 10 mrem	2SE-A	23.0	23.0
5 ≤ D < 100 mrem	3A	19.6	19.6
100 ≤ D < 500 mrem	4A	17.2	17.2
500 ≤ D < 1000 mrem	5A	16.2	16.2

Table 2 – MTA Longitudinal Shielding Thicknesses

Beam Type	Longitudinal Range	Location	Fixed Shielding (efd)	Movable Shielding (efd)	Current Shielding (efd)
	(z)				
P	0-41	Main Linac enclosure	14.9		14.9
P	41-55	Linac high ceiling	13.3		13.3
P	55-103	Linac ramp	15.7		15.7
P	103-106	Beam stop alcove		18.1	18.1
P	106-115	Hatch		21.7	21.7
P	115-147	MTA upstream stub	10.4		10.4

P	147-187	MTA main hall	10.6		10.6
P	187-193	Pipe to absorber	19.0		19.0
P	193-203	Absorber in berm	21.7		21.7

Table 3 - MTA Transverse Shielding Thicknesses

Beam Type	Transverse Station (ft)	Location	Fixed Shielding (efd)	Movable Shielding (efd)	Current Shielding (efd)
P	15	C-Magnet	13.0		13.0
P	45	13-ft Ceiling	11.9		11.9
P	57	10-ft Ceiling	14.2		14.2
P	104	Beam Stop Alcove		18.1	18.1
P	110	Hatch Waveguide		21.7	21.7
P	110	Hatch Waveguide		21.7	21.7
P	112	Hatch Waveguide		21.7	21.7
P	115	Hatch Waveguide		21.7	21.7
P	135	MTA Stub	10.4		10.4
P	157	MTA Exp Hall	10.2		10.2
P	167	MTA Rollup Door		15.0	15.0

III-2.4.1.1.2 *Penetration and movable Shielding*

The MTA does have a few areas where movable shielding is located. This includes vents and penetrations that are no longer used. The MTA has several penetrations routing between the enclosure and the counting house upstairs and have been addressed in the shielding assessment [2]. These penetrations leading to the counting house have been completely filled with polyethylene and sand. The hatch and ceiling vent leading to the MTA berm has been completely filled with sand and concrete. All moveable shielding has been verified by the Fermilab Radiation Protection Operations Department (RPO) and is a credited control. The RPO department utilizes a configuration management control system to ensure that all movable shielding is present and is an administrative credited control. All movable shielding at the MTA is covered and locked to also ensure that it remains in place. An interlocked radiation detector is placed in front of the penetrations in the counting house to protect personnel from the accident condition and again ensure that all dose rates remain below the posting limit for the area. This interlocked radiation detector is also a credited control.

III-2.4.2 Active Engineered Credited Controls

Active engineered controls are systems designed to reduce the risks from the MCI to an acceptable level. The active controls in place for the MTA operations are discussed below.

III-2.4.2.1 Radiation Safety Interlock System

The MTA enclosure employs a Radiation Safety Interlock System (RSIS). The characteristics of the system are described in Section I of the Fermilab SAD. There are interlocked doors at each of the two entrance labyrinth access points into the MTA enclosure. The interlock system inhibits transport of beam into the MTA enclosure except when the MTA enclosure is properly secured and locked.

The RSIS inhibits beam by controlling redundant critical devices. In this case, the E: UH101 power supply that feeds a four-magnet dipole bend string that directs beam to the MTA enclosure, and the UBS109 beam stop located at the entrance of the equipment hatch shielding that separates the Linac and MTA enclosures. In the event of a critical device failure, the system has a failure mode function that will reach back and inhibit beam to the Linac, thus eliminating the possibility of beam reaching the MTA.

The RSIS including requirements for hardware and system testing, inventory of interlock keys and procedures for maintenance of interlock systems. The RSIS hardware enforces the administrative Search and Secure and Controlled Access processes. The RSIS is designed, installed, and configuration managed in conformance with the requirements stated in the FRCM.

As mentioned above, with the MTA MCI having an intensity of $2.58E18$ protons/hr, the amount of permanent shielding needed to keep an individual exposure below 500 mrem in an hour is 17.2 e.f.d. This is the shielding between the interior surface of the enclosure walls and the nearest areas accessible by any individual. However, for the MCI, there are a number of areas along the MTA beamline that do not have the required shielding of 17.2 e.f.d. As a result, Interlocked radiation detectors are employed at those areas so that the same level of protection is provided and a dose to an individual standing in these areas will not receive a dose greater than 500 mrem in one hour. These radiation detectors are interlocked to the critical device controller (CDC), and if any one of them is absent from the CDC loop in the RSIS, beam cannot be transported to the MTA enclosure.

Interlocked radiation detectors are placed on the berm along the primary beamline and the experimental hall in those areas that are the most likely to be occupied at locations capable of detecting all accident conditions and are credited controls. They also serve to limit prompt dose to ensure compliance with FRCM requirements. Interlocked radiation detector trip limits, for the radiation detectors on the berm, should be set at 50 mrem/hr or less. Final locations and trip level settings of radiation detectors interlocked to the RSIS must have concurrence from the assigned Radiation Safety Officer. The operational posting limit for the MTA berm is 100 mrem/hr under the accident condition which automatically satisfies the ASE limit of 500 mrem in an hour. See Table 3.

Interlocked radiation detectors are capable of disabling beam within a maximum of 3 seconds to the MTA, allowing only 45 pulses into the MTA beamline in the event of an accident condition including initial detection of the event. This therefore limits the total number of protons delivered in an accident condition to 2.15×10^{15} . Interlocked radiation detectors on the berm have at least a 10' radius detection and therefore can be spaced ~20' apart on top of the berm. These interlocked radiation detectors will also

protect transverse shielding loss points. Based on the MCI analysis the following interlocked radiation detector are the credited controls. [6]

Table 4 - Interlocked radiation detectors at MTA

# of Interlocked radiation detectors needed	Interlocked Radiation Detector Location	Interlocked Radiation Detector Trip Limit
1	Linac High Ceiling	< 50 mrem/hr
1	Linac Ramp – top of berm Upstream	< 50 mrem/hr
1	Linac Ramp – top of berm Downstream	< 50 mrem/hr
1	Beam Stop Alcove – top of berm upstream of hatch	< 50 mrem/hr
1	MTA Upstream Stub- above UVB11 (SQA)	< 50 mrem/hr
1	MTA Hall – Ceiling Vent	< 50 mrem/hr
1	MTA Hall Mid-Hall	< 50 mrem/hr
1	MTA Hall “Front Porch”	< 50 mrem/hr
1	Pipe to Absorber	< 50 mrem/hr
1	MTA Counting House	< 5 Rem/hr

III-2.4.2.2 [ODH Safety System](#)

Oxygen Deficiency Hazards (ODH) due to cryogenic systems within accelerator enclosures have been identified as accelerator specific hazards, and as such, any preventative or mitigative controls used to prevent an ODH MCI are identified as credited controls and documented in the ASE. As part of the ITA experimental program, its possible for cryogenic liquids to be present in the MTA enclosure. As a result an analysis of this potential hazard has been performed. The amount of cryogenes an ITA experiment may bring into the MTA has been reviewed in engineering note EN08855 and will not exceed a liquid volume threshold of 34 liters. With this amount of cryogenic liquid, the oxygen concentration in the enclosure will never be lower than 19.5% and thus the ODH hazard remains negligible (category IV) at all times with no credited controls. As a result, an ODH Safety System is not needed at MTA.

III-2.4.3 [Administrative Credited Controls](#)

All MTA administrative credited controls are discussed below.

III-2.4.3.1 [Enclosure Search and Secure Process](#)

The “search and secure” process consists of a through exploration of the enclosure to ensure that the MTA RSIS area is not occupied. This process is completed by resetting the interlock boxes and a prescribed order in preparation for beam delivery. Trained and qualified personnel from the AD Operations

Department are required to search and secure the enclosure before permits from the RSIS may be reestablished following any personnel access to the enclosure, except under strictly specified controlled access conditions.

III-2.4.3.2 [Operation Authorization Document](#)

Beam will not be transported to the MTA enclosure without an approved Beam Permit and Running Condition. The Beam Permit specifies beam power limits as determined and approved by the AD Associate Laboratory Director, in consultation with the ES&H Radiation Physics Operations Department Head, ES&H Accelerator Safety Department Head, assigned RSO, AD Operations Department Head, and AD External Beams Department Head. The Running Condition for the MTA describes the operating configuration as reviewed by the assigned RSO, AD Operations Department Head, and AD External Beams Department Head and as approved by the AD Associate Laboratory Director.

III-2.4.3.3 [Staffing](#)

MCR must be appropriately staffed to ensure that a valid search and secure is performed for all enclosures, that all interlocked radiation detector trip limits are below the ASE limit and all beam losses stay under one hour in duration.

III-2.5. Defense-in-Depth Controls

Fermilab employs additional Defense in Depth (DD) controls to further reduce the possibility of an individual being exposed during an MCI. Some of the additional DD controls include an access gate that only allows badged employees access to the MTA area, service buildings with locked doors, and radiological fences keep individuals off the outside beamline berms.

III-2.5.1 [Fencing and Posting](#)

Fences are used and posted to designate potential Radiation Areas during machine operations. The MTA Shielding Assessment concluded that the radiation levels that can be expected along the MTA beamline require fences with a radiation area posting. The entire Linac berm along with the MTA beamline was fenced and posted consistent with its identification as a Radiation Area in accordance with the FRCM.

III-2.5.2 [Training](#)

All personnel engaged in the commissioning, operation, and emergency management of the Linac shall have at a minimum, Fermilab's Radiological Worker Training, Radiological Worker Just In Time Training and Radiological Worker Practical Factors Training. Furthermore, personnel approved for access into the MTA interlocked enclosure shall have Fermilab's Controlled Access training current as well.

Training in Fermilab's General or system specific Lock Out-Tag Out procedures shall be required to perform troubleshooting and maintenance as applicable.

III-2.5.3 [Procedures](#)

As applicable, either Fermilab's General Lock Out-Tag Out or Written Departmental Lock Out-Tag Out procedures shall be used. As per Fermilab's FESHM Chapter 2100, Written Departmental Safety procedures shall be reviewed and re-approved every twelve (12) months, at a minimum, or when the configuration of the equipment has been altered. Re-training for these procedures shall also be carried out every twelve (12) months to remain current.

III-2.6. Machine Protection Controls

Beam Loss Monitors routinely determine when beam is being lost at unacceptable regions and/or rates. Beam Position Monitors and multiwires determine the trajectories of the beam so that the Main Control Room may control losses. The Beam Budget Monitor continually monitors the integrated beam delivered to the MTA on an hourly basis.

III-2.7. Decommissioning

DOE Field Element Manager approval shall be obtained prior to the start of any decommissioning activities for MTA.

III-2.8. Summary and Conclusion

Specific hazards associated with commissioning and operation of the MTA beam line enclosure and experimental areas are identified and assessed in this Chapter of the Fermilab Safety Assessment Document. The designs, controls, and procedures to mitigate the MTA beam line specific hazards are identified and described. In addition to these specific safety considerations, the MTA beam line is subject to the global and more generic safety requirements, controls and procedures outlined in Section 1 of this Fermilab Safety Assessment Document.

The preceding discussion of the hazards presented by the MTA beamline and experimental operations and the credited controls established to mitigate those hazards demonstrate that the beamline can be operated in a manner that will produce minimal risks to the health and safety of Fermilab workers, visiting scientists, and the public, as well as to the environment.

III-2.9. References

- [1] Fermilab Radiological Control Manual
- [2] 2020 "Shielding Assessment Document for the MeV Test Area at the Fermilab Linac Endstation
- [3] Title 40, Code of Federal Regulations, Part 61, Subpart H, "National emissions standard for hazardous air pollutants (NESHAP) for the emission of radionuclides other than radon from Department of Energy Facilities", 1989.
- [4] MARS Code System Users Guide
- [5] Environmental Protection Notes
- [6] C. Johnstone, A Mazzacane and S. McGimpsey "Analysis of the Maximum Credible Incident for MeV Test Area Beamline and Hall", 2023

III-2.10. Appendix – Risk Matrices

Risk Assessment methodology was developed based on the methodology described in DOE-HDBK-1163-2020. Hazards and their potential events are evaluated for likelihood and potential consequence assuming no controls in place, which results in a baseline risk. A baseline risk (i.e., an unmitigated risk) value of III and IV does not require further controls based on the Handbook. Events with a baseline risk value of I or II do require prevention and/or mitigation measures to be established in order to reduce the risk value to an acceptable level of III or IV. Generally, preventive controls are applied prior to a loss event, reflecting a likelihood reduction, and mitigative controls are applied after a loss event, reflecting a consequence reduction. For each control put in place, likelihood or consequence can have a single “bin drop”, resulting in a new residual risk (i.e., a mitigated risk). This risk assessment process is repeated for each hazard for Facility Workers (FW), Co-Located Workers (CLW), and Maximally Exposed Offsite Individual (MOI). At the conclusion of the risk assessments, controls that are in place for the identified accelerator specific hazards are identified as Credited Controls and further summarized in Section III-2.3 of this Chapter as well as SAD Chapter VII-A.1 *Accelerator Safety Envelope – Fermilab Main Accelerator*.