

# Main Injector/Recycler Ring Maximum Credible Incident (MCI)

---

Martin Murphy

---

Fermilab  
Accelerator Directorate  
Beams Division  
Main Injector Dept.

Version 1.0  
February 2, 2024

## Maximum Credible Incident Analysis

This section of the MI/RR SAD evaluates the maximum credible incident (MCI) scenario that could happen in the lifetime of the MI/RR. Consideration and analysis of this MCI is focused on an onsite facility worker, onsite co-located worker, and a maximally exposed off-site individual (MOI).

## Radiological Hazard

The MI/RR are designed to transport and accelerate protons to downstream machines. There are many devices in these accelerators that accelerate, focus, and shape the beam pulses to ensure that a maximum number of protons reach the intended destination. Misdirection of this beam so that it impacts surrounding structures inside the accelerator enclosure can occur from a single failure of many of these devices or erroneous operation of them. An MCI would be one that produces the greatest prompt ionizing radiation from the beam loss.

There are a near-infinite number of individual beam loss events that can be postulated. The energy of these accelerators ranges between 8 and 120 GeV. The accelerators receive beam from the Booster accelerator at a maximum rate of 15Hz and a maximum intensity of  $7 \times 10^{12}$  protons per pulse. Beam loss can occur at any energy, but the MCI for these accelerators will be that of 120 GeV beam loss. These accelerators can deliver 12 Booster batches of 120 GeV beam every 1.067 seconds. Using these parameters and 100% transmission efficiency in the accelerators gives us:

$$12 \text{ [Booster batches/MI cycle]} * 7 \times 10^{12} \text{ [protons/batch]} * 3600 \text{ [seconds/hr]} / 1.067 \text{ [seconds/MI cycle]} = 2.83 \times 10^{17} \text{ [protons per hour].}$$

This analysis concludes that the maximum credible incident for the Fermilab MI/RR is a beam with an intensity of  $2.83 \times 10^{17}$  protons per hour at an energy of 120 GeV persistently incident on a beamline component for one hour.

### Event Causes:

1. The Booster accelerator is delivering beam with intensity of  $7 \times 10^{12}$  protons per pulse.
2. Beam transmission through the MI8 beamline, Recycler, and Main Injector is 100%.
3. Beam mis-steered at 120 GeV continually via any of the following events:
  - a. Failed magnet.
  - b. Operator error.
  - c. Autotune error.

Assuming no shielding is present, this incident would result in a dose to any individual higher than  $5.23 \times 10^7$  rem. The result is that the uncontrolled baseline qualitative risk level associated with this accident is not acceptable.

Fermilab uses Credited Controls that flow down to the Accelerator Safety Envelope (ASE) to mitigate the consequences of the MCI to the following conditions:

- **Worker Basis:** Mitigated consequence of any credible postulated accident scenario at maximum operating intensity that could potentially result in 5 rem in one hour in any area accessible by facility workers and co-located workers.
- **General Site Basis:** Mitigated consequence of any credible postulated accident scenario at maximum operating intensity that could potentially result in 500 mrem in one hour in areas to which the public is assumed to be excluded.
- **Public Area Basis:** Mitigated consequence of any credible postulated accident scenario at maximum operating intensity that could potentially result in 100 mrem in one hour at Fermilab's site boundary AND/OR in any areas onsite in which the public is authorized.
  - Batavia Road, Illinois Prairie Path (MBO), parking lots open to the public.
  - All General Access Areas including, but not limited to, the following:
    - Wilson Hall
    - Ramsey Auditorium
    - Lederman Science Center
    - Building 327

**These credited controls are discussed in Section III-7.4 of the Fermilab SAD.**

The accumulated dose outside of the shielding on the Main Injector berm is mitigated, by use of Credited Controls, to less than 500 mrem in an MCI. **Calculations by the Fermilab ES&H section show a person on the berm directly above the location of the MCI would receive an approximate total dose of 49.3 mrem in one hour.**

The closest location a member of the public is allowed to be, with respect to the MI/RR enclosure, is the site boundary near the MI30 section at Cell 318. The surveyed berm depth at this location is 24.1 efd. The site boundary is approximately about 200 feet away from the Main Injector berm at its closest point. **Conservative calculations by the ES&H section show a person at the site boundary would receive an approximate total dose of 0.25 mrem in one hour.** The calculation assumes the dose will be a line source, which is the worst case and least likely. As such one would expect the dose to fall as  $1/r$ , where  $r$  is the distance from the closest point of the berm to the site boundary.

The Illinois Prairie Path, which is a publicly accessed trail near of the Fermilab site boundary, is further away from the Cell 318 berm than the site boundary. At its closest point the trail is about 300 feet from the berm at MI Cell 318. **Assuming an MCI happened at that distance from the Illinois Prairie Path, a person would receive an approximate total dose of 0.16 mrem in one hour.** The calculation assumes the dose will be a line source, which is the worst case and least likely. As such one would expect the dose to fall as  $1/r$ , where  $r$  is the distance from the closest point of the berm to the Illinois Prairie Path.

## Conclusion

In the event of an MCI in the MI tunnel, in one hour a worker in a Main Injector service building would receive a total dose less than 5 rem. A worker on the berm would receive a total dose less than 500 mrem. Because the Main Injector exists behind controlled gates members of the public are neither invited nor expected in the Main Injector area of the site. Therefore, the radiological hazards to the public are limited

to areas near the site boundary, especially the Illinois Prairie Path, which is 300 feet from the nearest point to the Main Injector/Recycler Ring tunnel. Conservative analysis shows a member of the public in this area would receive a total dose less than 100 mrem/hour in an MCI condition.