

Tuesday, February 6th, 2024

Data Center Operational Highlights Week 6 - 2024

Incoming Hardware

- Nothing to report.

**facility ready indicates that data center/computer room have enough power, cooling, physical and loading capacity to support the hardware*

Corrective Maintenance

- On Thursday (2/1), Thermflo performed cleaning of FCC2 CRAC-6 condenser and replacement of a fan assembly on GCC CRAC-3 condenser. CRAC-6 and CRAC-3 are operational

Planned Maintenances (no impact)

- CHG000000022750: Volt Electric to perform IR Scanning this week (2/5 – 2/9) of Electric Panels in FCC, GCC, and WH8-FC (in progress)

Projects / Corrective Action (no impact)

- Nothing to report.

Miscellaneous

- Stable operation of the FCC and GCC data centers and WH8 Fiber Central.