

FAST / IOTA Shutdown 2023-2024

- **Enclosure STATUS:** ODH-0 & Supervised Access
- **General:** -ACNET alarms after power outage
- **ES&H:** -South gate of cave. OSC Mode continues in LL
- **IPI:**
 - 480/120VAC Electric Req “to be entered Monday”™
 - Alignment Crew back on Monday.
 - 6” coax completion on hold (Alignment)
 - Solenoid, Modulator, and CS cables routed
- **Cryo:** -Working on cryo system: repairs, testing, LN² #45, @5K Q3
- **Water:** -GN² Back-up system active. Chiller “waiting on contractor”™
- FAST/IOTA Collaboration Meeting March 12-14 a success
 - **Contact FAST RunCo with any work or access requests** —

ISD/CFM Report on NML Status

- **HiBay LEDs** in progress (again). **Hard Hats** under South Crane!
- **LED upgrade** (Exterior and Non-HiBay Interior) RFQ to contractors
- **Tunnel Lights** bulbs changed™ (again)
- **ICW** flushing this Spring.
- **Emergency Generator:**
 - New heater repaired™ (again) 03/12. Beeping has stopped™
- **Door handles** upgrade to ADA compliant
- **HV Electric** PM done Wednesday, 03/20, successfully.
- **ESB HVAC** install – still waiting on contract submittal
 - In Procurement™ (Summer?)