



U.S. DEPARTMENT OF
ENERGY


Office of
Science

Mu2e CD-2 Life Safety Review

Jim Niehoff

ES&H (Fire Protection) Safety Specialist

7/8/2014



Requirements (Objectives)

- Provide successful evacuation
- Provide effective fire fighting and rescue operation
- Limit spread of fire and smoke
 - Fire suppression systems
 - Fire alarm systems
 - Smoke abatement

Requirements (Determined)

- AON's recommendations are based on codes/orders/standards:
 - DOE Order 420.2C Safety of Accelerator Facilities
 - IBC (International Building Code)
 - IFC (International Fire Code)
 - NFPA (National Fire Protection Association)
- Aim of Life Safety
 - Get the occupants out (egress)
 - Get the fire fighters personnel in (ingress)
- Fire Protection approach is based on experience from previous projects at the laboratory


Design

- Less than 30 feet below level of exit discharge, omitting the requirements for smoke control and stairway pressurization
- Two Exit stairways enclosed by 2 hour fire rated construction
- Means to separate Enclosure from Detector Hall
- Maximum travel distance 300 feet
- Minimum aisle width 36 inches
- Automatic fire sprinkler system, preaction type (Detector Hall)
- Linear heat type detection
- Beam Type Smoke Detection & Spot Type Detection
- Air sampling smoke detection
- Manual pull stations


Design Continued

- Fire Alarm will have Emergency Voice Alarm system enable to interface with Fermilab's Site-wide Emergency Warning System
- Emergency and exit signage
- Emergency/Standby power systems
 - Fire alarm system
 - Exit signs
 - Emergency Lighting
 - Elevator
 - Sump System


DESIGN (Site Plan)




Fire Detection – Main Level




Fire Detection – Lower Level




Fire Suppression – Main Level



Fire Suppression – Main Level



Design (Section View)



Design (Detector Hall Detail)

